


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well: County Gray	Township name West Hess	Fraction NW Corner of SW/4	Section number 10	Town number T 27 S	Range number R 28 W
Distance and direction from nearest town or city: West of Cimarron, Ks		3 Owner of well: Don Renick Address: Ingalls, Ks. 67853			
Locate with "X" in section below: N 		Sketch map:		4 Well depth: 255 ft. Date of completion 2-10-75 Well diameter 26 in.	
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
				7 Casing: Material <u>Steel</u> Height: above <u>12</u> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>236</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight <u>56.87</u> lbs./ft. <u>1</u> <u>16</u> in. to <u>236</u> ft. depth	
				8 Screen: Manufacturer <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauge _____ Length <u>20'</u> Set between <u>170</u> ft. and <u>180</u> ft. <u>217-227</u> Pendings: <u>90-170, 180-217, 227-235</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>12"</u> down	
				9 Static water level: <u>88</u> ft. below land surface Date <u>2-11-75</u>	
				10 Pumping level below land surfaces: <u>107</u> ft. after <u>2</u> hrs. pumping <u>673</u> g.p.m. <u>181</u> ft. after <u>4</u> hrs. pumping <u>1170</u> g.p.m. Estimated maximum yield <u>1100</u> g.p.m.	
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
				12 Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade	
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite _____ Depth: From <u>0</u> ft. to <u>10</u> ft.	
				14 Nearest source of possible contamination: <u>N/A</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless-FMC</u> Model number _____ HP <u>75</u> Volts _____ Length of drop pipe <u>100</u> ft. capacity <u>600</u> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				16 Remarks: elevation <u>Fields surrounding well.</u> <u>Good Well.</u> Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley Electric motor (his own)	
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter-Wilson Drilling Co. 208</u> Business name <u>Box 493 Garden City, Ks.</u> License No. _____ Address _____ Signature <u>Minter-Wilson Drilling Co.</u> Date <u>6-20-75</u> Authorized representative _____	

WINTER-WILSON DRILLING CO. INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8260 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Gray County on Renick February 1975

S. 10 sec. 10 T. 27 R. 28 Static water Level: 75

Location: S. 10 sec. 10 T. 27 R. 28. Corner of 160 ft. South West of First
Test.

- 0 66 Fine Sand
- 6 47 Fine to Medium Sand & Brown Clay
- 47 77 Brown Sandy Clay & white rock
- 77 110 Fine to Medium Sand & Gravel (Small Streak of
coarse Gravel (Loose))
- 110 133 Brown Sandy Clay
- 133 140 Fine to Medium Sand & Gravel 100% Clay (Loose)
- 140 155 Brown Sandy Clay & white rock
- 155 159 Fine to Medium Sand & Gravel 20% Clay (Loose)
- 159 177 Fine to Medium Sand & Gravel (Loose)
- 177 217 Brown Clay
- 217 232 Fine to Medium Sand & Gravel (Loose) Good
- 232 238 Brown, Gray & Yellow Clay (Tight)
- 238 245 Shale (Hard)

TD 235