


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE $\frac{1}{4}$ NW $\frac{1}{4}$ SE $\frac{1}{4}$	Section number 17	Township number T 27 S	Range number R 28 H/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	9 $\frac{1}{2}$ south of Ingalls on the blacktop, 3 east, 3/4 south, $\frac{1}{4}$ west		3. Owner of well: R.R. or street: City, state, zip code:	Gene Smith Montezuma, Ks. 67867	
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 26 in. Completion date 12-31 Well depth 271 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material steel Height: Above ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 272 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze Length 20 ft. Set between 240 ft. and 260 ft. Perf: 120-240 ft. and 260-271 ft. Gravel pack? Yes Size range of material 1/2" down	11. Static water level: mo./day/yr. 83 ft. below land surface Date 12-25-76	
12. Pumping level below land surfaces: 105 ft. after 2 hrs. pumping 925 g.p.m. 121 ft. after 4 hrs. pumping 1900 g.p.m. Estimated maximum yield 1900 g.p.m.			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	14. Well head completion: Pitless adapter 12 inches above grade	
15. Well grouted? Yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No	17. Pump: Not installed Manufacturer's name Goulds-US Pump Model number 12 JHC HP 100 Volts Length of drop pipe 160 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)			18. Elevation:	19. Remarks:	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilg. Co. 208 Business name Address Box A Garden City, Ks. Signed <i>M. Minter</i> Date 5-13-77 Authorized representative <i>M. Minter</i>
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The Professionals* **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

(See)

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

GARDEN CITY  
GARDEN CITY

Location: S 27-23-20 1/4 Wt. south east of pivot

30' pivot

Static Water Level- 70 - 80'

Test #2

0	1	Top soil
1	5	Fine sand
6	73	Brown sandy clay
73	125	Med. coarse gravel
136	155	Light brown sandy clay mixed with white rock hard
155	211	Brown sandy clay
211	227	Brown sandy clay stks.
227	271	"ed. coarse gravel mixed yellow brown rock Loose
271	273	Yellow clay
275	276	Shale

T.D. 271'