


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 17	Township number T 27 S R 28	Range number 1/2
2. Distance and direction from nearest town or city: Street address of well location if in city:	9 1/2 south of Ingalls on the blacktop, 3 east, 1/4 south, 1/4 west		3. Owner of well: R.R. or street: City, state, zip code:	Gene Smith Montezuma, Ks. 67867	
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 26 in. Completion date 12-30-66 Well depth 266 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above <del>at bottom</del> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 267 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 250		
			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze Length 20 ft. Set between 230 ft. and 250 ft. Perf: 120-230 ft. and 250-266 ft. Gravel pack? <input type="checkbox"/> Yes Size range of material 1 1/2" down		
			11. Static water level: 79 ft. below land surface Date 12-18-76 mo./day/yr.		
			12. Pumping level below land surfaces: 103 ft. after 2 hrs. pumping 1225 g.p.m. 122 ft. after 4 hrs. pumping 2000 g.p.m. Estimated maximum yield 2000 g.p.m.		
			13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? <input type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name Goulds-US Pump Model number 12JHC HP 100 Volts Length of drop pipe 160 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter-Wilson Drilg. Co. 208 Business name <u>Box A</u> License No. Address <u>Garden City, Ks.</u> Signed <u>Gene Smith</u> Date <u>5-13-77</u> Authorized representative <u>Gene Smith</u> Date <u>5-13-77</u>		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

~~Form WWC-5~~

*The Professionals* **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

GENE SMITH  
GRAY COUNTY  
11-18-76

Location: NE 27-28-30 22 miles road south of Ingalls 3 miles  
east 2 3/4 miles north  $\frac{1}{4}$  mile west 30 Ft. north of pi  
pivot

Static Water Level- 70 - 80'

Test #1

0	6	Top soil
6	64	Brown sandy clay
64	109	Med. coarse gravel
109	117	Brown sandy
117	148	Fine to med. sand and gravel
148	172	Fine to med. sand and gravel Loose
172	203	Brown sandy clay
203	224	Brown sandy clay stks.
224	230	Fine to med. sand and gravel Brown yellow rock mi mixed Loose
230	266	Med. coarse gravel mixed yellow brown rock
266	269	Yellow clay hard pull down
269	272	Shale

T.D. 266