


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction NW NW SW 1/4 SW 1/4 SE 1/4	Section number #18	Township number T #27 S	Range number R #28 W
2. Distance and direction from nearest town or city: 8 miles south, 1 1/2 miles west of Cimarron, Ks.			3. Owner of well: John B. Unruh R.R. or street: City, state, zip code: Montezuma, Kansas 67867			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date Well depth 245 ft. 4-6-76		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil & clay		0	15	9. Casing: Material RMP Height: Above XXXX Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 245 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
Clay		15	45	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5@ Slot 1/8" Length 20 ft. Set between 220 ft. and 240 ft. ft. and 1 ft. Gravel pack? yes Size range of material 4		
Clay & fine sand		45	60	11. Static water level: 78 ft. below land surface Date 4-6-76		
Fine sand		60	75	12. Pumping level below land surfaces: 80 ft. after 1 hrs. pumping 50 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 80 g.p.m.		
Fine to medium sand		75	90	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Medium to coarse sand		90	105	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade		
" " "		105	120	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
Coarse sand & clay		120	135	16. Nearest source of possible contamination: ft. 70 Direction West Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Clay		135	150	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Flint & Walling Model number 10BK9 HP 1 Volts 230 Length of drop pipe 147 ft. capacity 19 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay layers & fine sand		150	165	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name License No. Address Box 174 Cimarron, Ks. Signed Lawrence C. Chick Date 6-16-76 Authorized representative		
Fine to medium sand & clay		165	180			
Medium sand & rock layers		180	195			
Medium sand		195	225			
Medium to coarse sand		225	250			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5