


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County GRAY	Fraction SW NW SW 1/4 NE 1/4 NW 1/4	Section number 23	Township number T 27 S	Range number R 28 E/W		
2. Distance and direction from nearest town or city: 6 1/2 Miles South of Cimarron, Ks. 1 mile West. 1/4 South 1/4 East			3. Owner of well: Ralph Fry R.R. or street: Montezuma, Ks. 67867 City, state, zip code:					
4. Locate with "X" in section below: 			Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 220 ft.			
5. Type and color of material			From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
							8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
							9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 20 1/2 in. Depth: Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth: gage No. 250	
							10. Screen: Manufacturer's name Johnson Division Galv. Dia. 16" Type <input type="checkbox"/> Slot/gauze 100 Length 20' Set between 160 ft. and 180 ft. Perf. 120-260 ft. and 180-220 ft. Gravel pack? yes Size range of material 3/8" Down	
							11. Static water level: 100 ft. below land surface Date 2-7-78	
(Use a second sheet if needed)							12. Pumping level below land surfaces: 116 ft. after 2 hrs. pumping 475 g.p.m. 128 ft. after 4 hrs. pumping 975 g.p.m. Estimated maximum yield 975 g.p.m.	
							13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
							14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
							15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
							16. Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
18. Elevation:			19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name P.O. Box A Garden City, Ks Address _____ Signed [Signature] Date 6-30 Authorized representative			
							17. Pump: Peerless-110 Not installed Manufacturer's name _____ Model number 05805 HP 100 Volts _____ Length of drop pipe 200 ft. capacity 950 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
							21. 27 28 29 30	
							22. 31 32 33 34	
							23. 35 36 37 38	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Phone 211-1111 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Ralph Fry (owner)
Pete Koehn (tenant)
Gray County
8-11-75

Location 2

Location: 1 mile north of Gray county Feedlot, 1 mile west,
 $\frac{1}{2}$ mile south, $\frac{1}{4}$ mile east NW $\frac{1}{4}$ 23-27-28

Test #1 Pivot

0	6	Sand & clay mixed
6	63	Brown clay
63	95	Fine to med. sand, 20% clay (loose)
95	110	Brown clay
110	129	Fine to med. sand & gravel, streaks of coarse gravel (loose)
129	142	Brown clay
142	187	Fine to med. sand & gravel (loose)
187	200	Fine to med. sand & gravel (tight)
200	213	Brown sandy clay
213	220	Fine to med. sand & fine gravel, 10% clay (loose)
220	233	Brown sandy clay & gray clay (tight)
233	240	Shale (hard)

Static Water Level: 87