


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 25	Township number T 27 S R 28 NW	Range number 28 NW
2. Distance and direction from nearest town or city: Cimarron, $\frac{1}{2}$ east Street address of well location if in city:	8 $\frac{1}{2}$ south of		3. Owner of well: Clayton Morrison R.R. or street: 2706 Pheasant City, state, zip code: Great Bend, KS 67530		
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. <u>26</u> in. Completion date <u>9-21-76</u> Well depth <u>250</u> ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <u>PVC</u> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>251</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>251</u> ft. depth Gage No. <u>12</u>		
5. Type and color of material	From	To	10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Galv</u> Dia. <u>16"</u> Slot/gauze <u>20</u> Ft Length <u>20</u> Ft Set between <u>180-220</u> ft. and <u>240-250</u> ft. Perf: <u>180-220</u> ft. and <u>240-250</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>9-17-76</u>		
			11. Static water level: <u>166</u> ft. below land surface Date <u>9-17-76</u>		
			12. Pumping level below land surfaces: <u>182</u> ft. after <u>3</u> hrs. pumping <u>1375</u> g.p.m. <u>182</u> ft. after <u>3</u> hrs. pumping <u>1375</u> g.p.m. Estimated maximum yield <u>1375</u> g.p.m.		
			13. Water sample submitted: <u>mo./day/yr.</u> <u>Yes</u> <input checked="" type="checkbox"/> <u>No</u> <u>Date</u>		
			14. Well head completion: <u>Pitless adapter</u> <u>12</u> Inches above grade		
			15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: ft. <u>Field</u> Direction <u>NE</u> Type <u>N/A</u> Well disinfected upon completion? <u>Yes</u> <input type="checkbox"/> <u>No</u>		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>Minter Wilson Drilling</u> Model number <u>208</u> HP <u>208</u> Volts Length of drop pipe <u>208</u> ft. capacity <u>208</u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling</u> <u>208</u> Business name <u>Box A Garden City, KS</u> License No. <u>614</u> Address <u>Box A Garden City, KS</u> <u>614</u> Signed <u>Minter Wilson Drilling</u> Date <u>2-24-77</u> Authorized representative <u>Minter Wilson Drilling</u>		
Topography:					
<input type="checkbox"/> Hill					
<input type="checkbox"/> Slope					
<input type="checkbox"/> Upland					
<input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The Professionals* **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846  
CLAYTON MORRISON  
Gray County  
8-5-76

Location: SW  $\frac{1}{4}$  25-27-28 1 mile south of Gray county  
feeders south of Cimmatron  $\frac{1}{4}$  east  $\frac{1}{4}$  north on pivot  
Static Water Level- 150'

Test #1

0	2	Top soil
2	17	Brown clay
17	34	Brown sandy clay
34	52	Fine to med. sand and fine gravel
52	80	Fine to med. sand and gravel
80	126	Fine to med. sand and fine gravel 10% clay
126	155	Brown clay
155	245	Fine to med. sand and gravel 10% clay
245	249	Yellow clay and white rock hard
249	255	Shale

T.D. 250'  
Screen 20