

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 NE 1/4 SE 1/4	Section number 29	Township number T 27 S	Range number R 28 E
2. Distance and direction from nearest town or city: Montezuma 4 1/2 North East - 1/4 North-West into quarter		3. Owner of well: Denton Unruh R.R. or street: Montezuma, Ks. 67867 City, state, zip code:			
4. Locate with "X" in section below: Sketch map: N 1 Mile W E S 1 Mile		6. Bore hole dia. 26 in. Completion date 1-31-77 Well depth 248 ft. 7. Cable tool Rotary Driven Dug Hollow rod Jetted Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: Domestic Public supply Industry <input checked="" type="checkbox"/> Irrigation Air conditioning Stock Lawn Oil field water Other 9. Casing: Material steel Height: Above surface Threaded Welded <input checked="" type="checkbox"/> Surface 12 in. RMP PVC Weight 36.87 lbs./ft. Dia. 16 in. to 249 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 250			
5. Type and color of material		From	To	10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot 1/8" Length 10 ft. Set between 180-190 ft. and 230-240 ft. Perf. 140-180 ft. and 190-230 240-248 Gravel pack? yes Size range of material 3" down	
				11. Static water level: mo./day/yr. 104 ft. below land surface Date 12-22-76	
				12. Pumping level below land surfaces: 113 ft. after 2 hrs. pumping 900 g.p.m. 119 ft. after 4 hrs. pumping 1500 g.p.m. Estimated maximum yield 1500 g.p.m.	
				13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: Pitless adapter 12 inches above grade	
				15. Well grouted? yes With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No	
				17. Pump: Not installed Manufacturer's name Goulds - US PUMP Model number 12JHC HP 100 Volts Length of drop pipe 120 ft. capacity 1000 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. inter-Wilson Drilling Co. 208 Business name License No. Address Box A Garden City, Ks. Signed [Signature] Date 1-30-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DENTON UNRUH
ZIMMERMAN (OWNER)
GRAY COUNTY
11-12-76

Location: SE 29-27-28 south of Ingalls to 22 mile road 3 miles
east $\frac{1}{4}$ north $\frac{1}{4}$ west

Static Water Level- 100'

Test #1

0	7	Sand and clay mixed
7	37	Brown clay
37	50	Sand and clay
50	67	Fine to med. sand and gravel Loose
67	95	Brown clay and white rock tight
95	197	Fine to med. sand and gravel Loose
197	230	Brown clay
230	248	Fine to med. sand and gravel Loose
248	260	Brown sandy clay
260	268	Brown clay and white rock Hard
268	275	Shale Hard

T.D. 248'

140' Plain
40' Perf
10' Screen
40' Perf
10' Screen
8' Perf
248'