

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

The
Professionals

MINTER-WILSON DRILLING CO. INCORPORATED

Drillers
and Contractors
to the Oil and
Gas Industry

Phone: 276-8160 • P.O. Box A • GARDEN CITY, KANSAS 67846

CARL LOVE
GRAY COUNTY
4/24/78

Location: SW 31-27-28 south of Ingalls to 23 mile road
1 mile east, $\frac{1}{4}$ mile north 500ft. north east of
pivot or 200 ft. north of best test.

Static Water Level- 95'

Test #1

0	6	Top soil
6	22	Brown clay
22	32	Fine sand 20% clay
32	51	Brown clay
51	59	Fine sand
59	101,	Brown sandy clay
101	119	Fine to med. sand and gravel Loose
119	125	Brown sandy clay
125	133	Fine to med. sand and gravel 15% clay Tight
133	181	Fine to med. sand and gravel
181	195	Brown sandy clay mixed with rock Hard
195	240	Brown sandy clay
240	257	Yellow clay mixed with yellow rock No Good
257	260	Shale

TD 191