

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Gray Co.	County	Fraction 1/4 1/4 NW 1/4	Section number 31	Township number T 27 S.	Range number S R 28 E. E/W
2. Distance and direction from nearest town or city: South of Ingalls to 22 mile road 1 mile East 3/4 mile North 1/4 East or street: Street address of well location if in city 300 ft. North of Pivot City, state, zip code: Montezuma, Kansas 67867					
4. Locate with "X" in section below: 			Sketch map:		
			6. Bore hole dia. 26 in. Completion date 6-30-78 Well depth 205 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 205 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Johnson
					Type Johnson Galv. 100 16" Slot/gauze 120-150 Perf ft. Set between 150-200 Screen ft. 200-205 ft Perf ft. Gravel pack? yes Size range of material 1/8 to 5/8
					11. Static water level: 92 ft. below land surface Date 5-22-78 mo./day/yr.
					12. Pumping level below land surfaces: 105 ft. after 2 hrs. pumping 900 g.p.m. 111 ft. after 2 hrs. pumping 1350 g.p.m. Estimated maximum yield 1350 g.p.m.
					13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? Yes <input type="checkbox"/> No <input type="checkbox"/>
					17. Pump: Not installed Manufacturer's name Gould - 5 stage 12" Model number JLC HP 125 Volts <input type="checkbox"/> Length of drop pipe 190 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley
			19. Remarks:	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drig. 208 Business name <input type="checkbox"/> Address Box A, Garden City, KS Signed <input type="checkbox"/> Date 9-9-78 Authorized representative <input type="checkbox"/>	

For
Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

CARL LOVE
GRAY COUNTY
4/24/78

Location: NW 31-27-26 south of Ingalls to 22 mile road
1 mile east, 3/4 north, 1/4 east, 300 ft.
north of Pivot

Static Water Level- 95'

Test #2

0	6	top soil
6	37	Brown clay
37	63	Fine sand
63	92	Brown sandy clay
92	109	Fine to med. sand and gravel Loose
109	113	Brown sandy clay
113	171	Fine to med. sand and gravel Loose
171	187	Brown sandy clay
187	202	Fine to med. sand and gravel Loose
202	231	Yellow clay mixed with rock hard
231	235	Shale

TD 205

120 Plain
30 Perf
20 Screen
20 Perf
10 Screen
5 Perf