


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction SW _{1/4} NE 1/4 SW 1/4	Section number 35	Township number 27	Range number S R 28
2. Distance and direction from nearest town or city: of Cimarron	9 3/4 miles south of Cimarron				
Street address of well location if in city:	Bob Kinneman Montezuma, Ks. 67867				
4. Locate with "X" in section below:	Sketch map: 				
5. Type and color of material	From	To			
6. Bore hole diameter in. Completion date	26	5-31-76			
Well depth ft.	262				
7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material <input type="checkbox"/> steel <input checked="" type="checkbox"/> iron Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 6 in. to 24 ft. depth Wall thickness: inches or Dia. 10 in. to 30 ft. depth gage No. 12					
10. Screen: Manufacturer's name GATES					
Type <input type="checkbox"/> 10 in. Dia. 10 in.					
Slot/gauge <input type="checkbox"/> 100 Length 20 ft.					
Set between 230 ft. and 250 ft.					
Perf. 190-230 ft. and 250-262 ft.					
Gravel pack? <input type="checkbox"/> Size range of material <input type="checkbox"/> 10 in. Dia. 12					
11. Static water level: <input type="checkbox"/> 180 ft. below land surface Date 1-13-76					
12. Pumping level below land surfaces: 2000 ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> 2000 g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.					
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date					
14. Well head completion: Pitless adapter <input type="checkbox"/> 12 inches above grade					
15. Well grouting: <input type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.					
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> FMC Peerless Pump Model number <input type="checkbox"/> FMC HP 125 Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> 240 ft. capacity <input type="checkbox"/> 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:	19. Remarks: Drilling done by: Central Well & Pump Pratt, Ks.				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson drilling 208 Business Name: Box A Garden City, Ks. Address: <i>Minter Wilson</i> Signature: <i>Minter Wilson</i> Date: 8-19-76 Authorized representative				

The Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

and DOMESTIC
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

**BOB KINNAMON
GRAY COUNTY
2-20-76**

**LOCATION: SW 36-27-28
From South West Corner, Go 540 Yards North,
30 Feet East In Field**

STATIC WATER LEVEL: 170

TEST #3

0	14	Top Soil
14	23	Fine Sand
23	63	Brown Sandy Clay
63	83	Brown Sandy (10%) Sand
83	104	Brown Sandy Clay (20%) Gravel
104	180	Brown Sandy Clay, Sand Streak
180	186	Fine To Med. Sand (Tight)
186	197	Fine To Med. Sand & Gravel
197	204	Brown, Yellow Clay
204	230	Fine To Med. Sand & Gravel (Loose)
230	262	Fine To Med. Sand & Gravel, Some Coarse Gravel (Loose)
262	268	Yellow, Gray Clay
268	271	Shale

TD 262
Screen 20'