


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 1	Township number T 27	Range number S 29	H/W		
2. Distance and direction from nearest town or city: Street address of well location if in city:	3. Owner of well: R.R. or street: City, state, zip code:					Jim Schmidt Montezuma, Ks. 67867		
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. 26 in. Completion date 2-28-77 Well depth 256 ft.		
						7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
						9. Casing: Material <input checked="" type="checkbox"/> Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 257 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 219		
5. Type and color of material	From	To				10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze 200-210 Length 10 ft. Set between 240-250 ft. and 240-250 ft. Perf: 125-142 ft. and 178-200, 210-240, 256 ft. Gravel pack? yes Size range of material 2" down		
						11. Static water level: 100 ft. below land surface Date 12-17-76		
						12. Pumping level below land surfaces: 129 ft. after 2 hrs. pumping 600 g.p.m. 140 ft. after 4 hrs. pumping 800 g.p.m. Estimated maximum yield 800 g.p.m.		
						13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
						14. Well head completion: Pitless adapter 12 inches above grade		
						15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
						16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
						17. Pump: Manufacturer's name Customer's pump Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Customer furnished his own pump.	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Inter-Wilson Drilg. Co. 208 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address <input type="checkbox"/> Box A Garden City, Ks. Signed <input type="checkbox"/> Date 3-23-77 Authorized representative <input type="checkbox"/>

