


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

_____ T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name	Fraction NW SE NW	Section number 4	Town number T27S	Range number R 29W
Distance and direction from nearest town or city: Approx. 6 S. 82 W from Ingalls			3 Owner of well: Dave Minet 1307 Ave B Dodge City, Ks			
Street address of well location if in city:			Address:			
Locate with "X" in section below: 			Sketch map:			
<p>4 Well depth: 229 ft. Date of completion 5 May 75 Well diameter 28 in.</p> <p>5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well</p> <p>7 Casing: Material steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 229 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No Weight 32 lbs./ft.</p> <p>8 Screen: Manufacturer Cook, Brown & Foster Type WW Jouver Dia. T mill slot 16" Slot/gauze 1/8" Length 146' Set between 83 ft. and 229 ft. Fittings: 1 - 9 mm Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material</p> <p>9 Static water level: 23 ft. below land surface Date 13 Jan 75</p> <p>10 Pumping level below land surfaces: 89 ft. after 1 hrs. pumping 1080 g.p.m. 127 ft. after 1 hrs. pumping 2276 g.p.m. Estimated maximum yield 2500 g.p.m.</p> <p>11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date</p> <p>12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade</p> <p>13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite</p> <p>Depth: From 0 ft. to 10 ft.</p> <p>14 Nearest source of possible contamination: Link ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 12KH HP 100 Volts _____ Length of drop pipe 160 ft. capacity 1300 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p> <p>16 Remarks: elevation (use a second sheet if needed)</p> <p>17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co 150 Business name _____ License No. _____ Address Garden City Signed R. J. Layne Date _____ Authorized representative 16 May 75</p>						



TEST HOLE REPORT

Layne-Western Company, Inc.

WATER SUPPLY SERVICES SINCE 1924—

TEST DRILLING • WATER WELLS • PUMPS
P.O. Box 686 - W. Hwy. 50
Garden City, Kansas 67846

Contract Name Dave Minet

Job No. K-371 Date 1-19-74

City Dodge City State Kansas

TEST HOLE
No. 1-74

Location of Test Hole Center of

Elevation of Test Hole

Static Water Level 73'

Measured in well Hours After Completion

1/4 NW 1/4 Sec. 4 of T 27S,
R 29W, Gray Co., Kansas.

Remarks.