



USE THIS WRITER OR BALL  
POINT PEN ONLY, PRINT CLEARLY,

PRINT CLEARLY

ENVIRONMENTAL

HEALTH

WATER WELL RECORD  
KSA 82a-1201-1215

\_\_\_\_\_ T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well County Gray	Township name Copeland	Fraction NW <sup>1</sup> / <sub>4</sub>	Section number 6	Town number 27	Range number 29
Distance and direction from nearest town or city: 13 Miles North and 6 Miles East of Street address of well location if in city: Copeland		3 Owner of well: Charles Withers Address: Satanta, Kansas			
Locate with "X" in section below: N  W E S 1 Mile		Sketch map:		4 Well depth: 200 ft. Date of completion 4-7-75 Well diameter 26 in. 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
				7 Casing: Material steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 200 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight lbs./ft. 16 in. to 200 ft. depth	
2 Type and color of material		From	To	8 Screen: W A Brown Manufacturer _____ Type Free Flo Dia. 16 Slot/gauze Slot Length 2" Set between 120 ft. and 200 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 5/8	
Topsoil		0	7	9 Static water level: 62 ft. below land surface Date June 1974	
Clay		7	15	10 Pumping level below land surfaces: Not test Pumped ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
Sand		15	58	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Coarse Sand		58	98	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
Sand to Clay		98	125	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite _____ Depth: From 0 ft. to 10 ft.	
Clay		125	127	14 Nearest source of possible contamination: None ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Sand and Gravel		127	147	15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay		147	150	16 Remarks: elevation	
Sand and Gravel		150	200	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dunham Drilling Co. 223 Business name Copeland, Kansas License No. Address _____ Signed _____ Date 6-20-75 Authorized representative _____	
Clay		200	215	(use a second sheet if needed)	