


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE $\frac{1}{4}$ NW $\frac{1}{4}$ SE $\frac{1}{4}$	Section number 6	Township number T 27	Range number S R 29 E	
2. Distance and direction from nearest town or city: 2 South, 1 East, 2 South, 1 East, $\frac{1}{4}$ North, 300 yds. West Street address of well location if in city: of Charleston, Kansas	3. Owner of well: R.R. or street: City, state, zip code: Herb Hoge 719 N. 1st Cimarron, KS 67835					
4. Locate with "X" in section below: N 	Sketch map:					
5. Type and color of material	From	To	6. Bore hole dia. 20 in. Completion date 10-15-75 Well depth 230 ft.			
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Steel Height: Above <input type="checkbox"/> Below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 231 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			
			10. Screen: Manufacturer's name Johnson Division Type Galvanized Dia. 16"			
			Slot/gage <input type="checkbox"/> Length 20' Set between 200 ft. and 220 ft. Perf: 100-200 ft. and 220-230 ft. Gravel pack? Yes Size range of material 15" Down			
			11. Static water level: mo./day/yr. 71 ft. below land surface Date 9-27-75			
			12. Pumping level below land surfaces: 85 ft. after 2 hrs. pumping 869 g.p.m. 91 ft. after 4 hrs. pumping 1288 g.p.m. Estimated maximum yield 1280 g.p.m.			
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
			15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type N/A Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No			
			17. Pump: Manufacturer's name Goulds - US Pump Model number 100 HP 100 Volts Length of drop pipe 180 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 208 Business name <input type="checkbox"/> License No. Address Box A, Garden City, KS Signed <input type="checkbox"/> Authorized representative Date 3-23-76
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

*The  
Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Herb Hoge  
Gray County  
9-5-75

Location: SE 6-27-29  
650 ft. East of Pivot Point South  $\frac{1}{4}$

Test # 4

0	1	Top Soil
1	8	Brown Clay
8	50	Fine to Med. Sand & Brown Clay
50	67	Fine to Med. Sand & Gravel, Streaks of Course Gravel (Loose)
67	80	Brown Clay
80	98	Med. to Course Gravel (Loose)
98	110	Brown Clay & White Rock, 35% Gravel (Loose)
110	127	Fine to Med. Sand & Gravel (Loose)
127	140	Fine to Med. Sand & Fine Gravel (Loose)
140	155	Brown Clay, Streaks of Fine to Med. Sand & Grav 30%
155	169	Fine to Med. Sand & Fine Gravel (Loose)
169	200	Fine to Med. Sand & Gravel 10% Clay (Loose)
200	230	Fine to Med. Sand & Gravel (Loose)
230	245	Brown Sandy Clay
245	250	Brown & Yellow Clay with White Rock (Hard)

TD 230'