


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction 1/4	PIVOT 1/4 NE 1/4	Section number 6	Township number T 27 S	Range number R 29
2. Distance and direction from nearest town or city: 2 South, 1 East, 2 South, 1 East, 3/4 North, 1/4 West of Street address of well location if in city: Charleston, Kansas	3. Owner of well: R.R. or street: City, state, zip code: Herb Hoge 719 N. 1st Cimarron, Kansas 67835					
4. Locate with "X" in section below: 	Sketch map:			6. Bore hole dia <u>26</u> in. Completion date <u>10-15-75</u> Well depth <u>241</u> ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <u>Steel</u> Height: Above <u>surface</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <u>16</u> in. to <u>242</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>242</u> ft. depth Gage No. Dia. <u>16</u> in. to <u>242</u> ft. depth Gage No.			
			10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galvanized</u> Dia. <u>16"</u> Slot/gauze <u>200</u> Length <u>200</u> Set between <u>100-200</u> ft. and <u>220-240</u> ft. Perf: <u>100-200</u> ft. and <u>220-240</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>2"</u> down			
			11. Static water level: <u>91</u> ft. below land surface Date <u>9-24-75</u> mo./day/yr.			
			12. Pumping level below land surfaces: <u>104</u> ft. after <u>2</u> hrs. pumping <u>863</u> g.p.m. <u>109</u> ft. after <u>11</u> hrs. pumping <u>1288</u> g.p.m. Estimated maximum yield <u>1280</u> g.p.m.			
			13. Water sample submitted: <u>Yes</u> Date <u>9-24-75</u> mo./day/yr.			
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade			
			15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
			16. Nearest source of possible contamination: ft. <u>0</u> Direction <u>NE</u> Type <u>N/A</u> Well disinfected upon completion? <u>Yes</u> <input checked="" type="checkbox"/> No			
			17. Pump: Not installed Manufacturer's name <u>Goulds - US Pumps</u> Model number <u>HP 100</u> Volts <u>110</u> Length of drop pipe <u>180</u> ft. capacity <u>1250</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter-Wilson Drilling</u> 208 Business name <u>Box A, Garden City, KS</u> License No. Address <u>Box A, Garden City, KS</u> Signed <u>John Minter</u> Date <u>10/15/75</u> Authorized representative <u>John Minter</u> Date <u>10/15/75</u>		
18. Elevation:	19. Remarks: USED CASING					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Herb Hoge
Gray County
9-5-75

Location: NW 6-27-29
Pivot Point North

Test # 2

0	1	Top Soil
1	6	Brown Clay
6	37	Fine to Med. Sand
37	50	Brown Clay & White Rock
50	67	Fine to Med. Sand, Streaks of Clay
67	92	Fine to Med. Sand & Gravel (Loose)
92	127	Fine to Med. Sand & Gravel, Streaks of Course Gravel (Loose)
127	217	Fine to Med. Sand & Gravel (Loose)
217	241	Fine to Med. Sand & Gravel, 10% Clay (Loose)
241	246	Brown Clay
246	258	Brown Clay (Hard Streaks)
258	261	Brown & Yellow Clay (Hard)
261	265	Shale (Hard)

TD 241'