

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE $\frac{1}{4}$ SW $\frac{1}{4}$ NE $\frac{1}{4}$	Section number 10	Township number T 27 S	Range number R 29 $\frac{1}{4}$ W
2. Distance and direction from nearest town or city: Street address of well location if in city:	7 $\frac{1}{2}$ south of Ingalls $\frac{1}{4}$ west, $\frac{1}{4}$ south.		3. Owner of well: R.R. or street: City, state, zip code:	Everett Schilling Montezuma, Ks. 67867	
4. Locate with "X" in section below:	<p>Sketch map: N</p>		<p>6. Bore hole dia. <u>26</u> in. Completion date <u>12-27-76</u> Well depth <u>300</u> ft.</p> <p>7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material <u>steel</u> Height: Above <u>surface</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <u>0</u> PVC <u>0</u> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>301</u> ft. depth Wall Thickness: inches or Dia. <u>0</u> in. to <u>0</u> ft. depth Gage No. <u>250</u></p> <p>10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Galv.</u> Dia. <u>16</u> Slot/gauge <u>0.0625</u> Length <u>20ft.</u> Set between <u>270</u> ft. and <u>290</u> ft. Perf: <u>130-270</u> ft. and <u>290-300</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1"</u> down</p> <p>11. Static water level: <u>94</u> ft. below land surface Date <u>12-14-76</u> mo./day/yr.</p> <p>12. Pumping level below land surfaces: <u>106</u> ft. after <u>2</u> hrs. pumping <u>1100</u> g.p.m. <u>118</u> ft. after <u>4</u> hrs. pumping <u>2050</u> g.p.m. Estimated maximum yield <u>2050</u> g.p.m.</p> <p>13. Water sample submitted: <u>no</u> mo./day/yr. <u>no</u> Yes <input checked="" type="checkbox"/> No Date</p> <p>14. Well head completion: <u>Pitless adapter</u> <u>12</u> Inches above grade</p> <p>15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.</p> <p>16. Nearest source of possible contamination: ft. <u>0</u> Direction <u>0</u> Type <u>N/A</u> Well disinfected upon completion? <u>no</u> Yes <input checked="" type="checkbox"/> No</p> <p>17. Pump: Not installed Manufacturer's name <u>Goulds-US Pump</u> Model number <u>12JHMO</u> HP <u>0.5</u> Volts <u>115</u> Length of drop pipe <u>160</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p> <p>18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley</p> <p>19. Remarks: Customer furnished electric motor.</p> <p>20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drig. Co. <u>208</u> Business name <u>Box A Garden City, Ks.</u> License No. Address <u>Box A Garden City, Ks.</u> Signed <u>Michael J. Wilson</u> Date <u>5-13-77</u> Authorized representative <u>Michael J. Wilson</u></p>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

EVERETT SCHILLING
GRAY COUNTY
11-19-76

Location: NE 10-27-29 7 $\frac{1}{2}$ miles south of Ingalls 4 west 60 Ft
east of pivot
Static Water Level- 90'

Test #1

0	9	Top soil
9	33	Brown sandy clay
33	50	Brown sandy clay 15% sand
50	67	Brown sandy clay
67	81	Brown sandy clay 10% sand stks.
81	92	Med. sand to med. coarse gravel
92	93	Brown sandy clay
93	116	Fine to med. sand and gravel
116	126	Brown sandy clay 10% gravel stks.
126	150	Fine to med. sand and gravel
150	153	Brown clay
153	167	Fine to med. sand
167	172	Brown clay
172	187	Fine to med. sand and gravel small clay stks.
187	204	Brown clay
204	212	Clay and gravel layer 50.50%
212	233	Med. coarse gravel mixed brown yellow rock
233	256	Med. coarse gravel mixed brown yellow rock Loose
256	268	Brown sandy clay
268	300	Med. sand to med. coarse gravel mixed yellow brown rock
300	305	Yellow clay and shale

T.D. 300'

130' Plain
140' Perf
20' Screen
10' Perf

2-copy log