


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 17	Township number T 27 S R 29	Range number 10
2. Distance and direction from nearest town or city: 11 south of Ingalls	Owner of well: Richard Jantz				
4 west 1/8 north Street address of well location if in city:	R.R. or street: Montezuma, KS 67867				
4. Locate with "X" in section below: 	Sketch map:		6. Bore hole dia. 26 in. Completion date 12-20-76 Well depth 240 ft.		
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material <input type="checkbox"/> steel <input checked="" type="checkbox"/> cast iron <input type="checkbox"/> concrete Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP 36.87 lbs./ft. Dia. 16 in. to 241 ft. depth Wall thickness: inches or Dia. 16 in. to 241 ft. depth Gage No.					
10. Screen: Manufacturer's name Johnson Screen Type Galv. Dia. 16" Slot/gauze 200 Length 20' Set between 200 ft. and 220 ft. Perf: 120-200 ft. and 220-240 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1-1/2" - 2"					
11. Static water level: mo./day/yr. 79 ft. below land surface Date 12-10-76					
12. Pumping level below land surfaces: 89 ft. after 2 hrs. pumping 1150 g.p.m. 95 ft. after 4 hrs. pumping 1550 g.p.m. Estimated maximum yield 1550 g.p.m.					
13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date					
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade					
15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds US Pumps Model number 12JHG HP 125 Volts 110 Length of drop pipe 180 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					
19. Remarks: (Use a second sheet if needed)					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name P.O. Box A Garden City, KS Address 1200 S. 24th Signed Minter Wilson Date 12-10-76 Authorized representative					

WINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

RICHARD JANTZ

GRAY COUNTY

9-9-76

Location: SW $\frac{1}{4}$ 17-27-29 from south west corner go 800 Ft. n
north 70 Ft. east of ditch

Static Water Level- 85'

Test #2

0	1	Top soil
1	5	Fine sand
5	25	Brown clay
25	30	Fine sand
30	40	Brown sandy clay
48	59	Med. sand to med. coarse gravel
59	140	Med. coarse gravel
140	156	Med. sand to med. coarse gravel
156	166	Med. coarse gravel
166	183	Brown sandy clay
183	203	Fine to med. sand 20% clay
203	210	Fine to med. sand and gravel
210	216	Med. sand to med. coarse gravel mixed with rock
216	226	Med. coarse gravel mixed white brown rock
226	233	Brown sandy clay
233	240	Fine to med. sand and gravel
240	247	Brown sandy clay Hard
247	255	Yellow clay mixed with rock Hard Pull Down
255	260	Shale