


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

<input checked="" type="checkbox"/> Location of well:	County	Fraction	Section number	Township number	Range number	
	Gray	NE 1/4 SW 1/4 SW 1/4	20	T 27	S R 29	EN
<input checked="" type="checkbox"/> Distance and direction from nearest town or city:	10 S & 3 E of Ingalls, Kansas		3. Owner of well: Frank D. Unruh			
Street address of well location if in city:				R.R. or street: Box 112		
				City, state, zip code: Montezuma, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date 5-13-76 Well depth 292 ft.		
 Center of the SW <sup>1/4</sup> , Sec. 20 of T27S, R29W, Gray County, Kansas				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 102 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Doerr and Foster		
Sandy soil		0	2	Louver & Millislot Dia. 16 <sup>11</sup> Slot/gauze 1/8" Length 190! Set between 102 ft. and 292 ft. ft. and ft. Gravel pack? Yes Size range of material 6mm		
Tan clay		2	32	11. Static water level: Unk mo./day/yr. ft. below land surface Date		
White clay and sand		32	57	12. Pumping level below land surface: No Test ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 2000 g.p.m.		
Fine to coarse sand med. gravel, coarse gravel		57	165	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Tan clay with sand and gravel		165	201	14. Well head completion: Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Coarse sand medium gravel		201	292	15. Well grouted? Yes With: Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Black shale		292	300	16. Nearest source of possible contamination: Unk ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump His Own Not installed Manufacturer's name UNK Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				18. Elevation: 19. Remarks:  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Layne - Western Co.</b> 150 Business name <b>Garden City</b> License No. Address <b>5-21</b> Signed <b>R. L. Vincent</b> Date <b>5-21-76</b> Authorized representative		