

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: <u>Gray</u>	<u>NE 1/4 NE 1/4 SE 1/4</u>	<u>24</u>	T <u>27</u> S	R <u>29</u> E <u>MD</u>

Distance and direction from nearest town or city street address of well if located within city?

From Montezuma east edge five and 3/4 miles North.

2 WATER WELL OWNER: <u>Mrs. Bindley</u>	Board of Agriculture, Division of Water Resources
RR#, St. Address, Box #: <u>Rt. 2</u>	Application Number:
City, State, ZIP Code: <u>Montezuma, KS. 67867</u>	

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: <u>31.5'</u> ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. .... ft. 2. .... ft. 3. .... ft.
	WELL'S STATIC WATER LEVEL <u>15.5'</u> ft. below land surface measured on mo/day/yr <u>10-13-93</u>
	Pump test data: Well water was .... ft. after .... hours pumping .... gpm
	Est. Yield .... gpm: Well water was .... ft. after .... hours pumping .... gpm
	Bore Hole Diameter <u>7 7/8"</u> in. to .... ft., and .... in. to .... ft.
WELL WATER TO BE USED AS:	
<input checked="" type="checkbox"/> 1 Domestic <input type="checkbox"/> 3 Feedlot <input type="checkbox"/> 6 Oil field water supply <input type="checkbox"/> 9 Dewatering <input type="checkbox"/> 12 Other (Specify below)	
<input type="checkbox"/> 2 Irrigation <input type="checkbox"/> 4 Industrial <input type="checkbox"/> 7 Lawn and garden only <input type="checkbox"/> 10 Monitoring well	
Was a chemical/bacteriological sample submitted to Department? Yes.....No... <u>X</u> ....; If yes, mo/day/yr sample was submitted	
Water Well Disinfected? Yes <u>X</u> No	

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued <u>X</u> Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)
<u>2 PVC</u>	4 ABS	7 Fiberglass	11 Injection well
Blank casing diameter <u>5"</u> in. to <u>29.5'</u> ft., Dia. .... in. to .... ft., Dia. .... in. to .... ft.			12 Other (Specify below)
Casing height above land surface <u>18"</u> in., weight .... lbs./ft. Wall thickness or gauge No. <u>SDR 21</u>			
TYPE OF SCREEN OR PERFORATION MATERIAL:			
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS
SCREEN OR PERFORATION OPENINGS ARE:			
1 Continuous slot	3 Mill slot	5 Gauzed wrapped	8 Saw cut
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes
SCREEN-PERFORATED INTERVALS: From <u>29.5'</u> ft. to <u>31.5'</u> ft., From .... ft. to .... ft.			
GRAVEL PACK INTERVALS: From <u>20</u> ft. to <u>31.5'</u> ft., From .... ft. to .... ft.			

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	<u>3 Bentonite</u>	4 Other
Grout Intervals: From <u>0</u> ft. to <u>20'</u> ft., From .... ft. to .... ft., From .... ft. to .... ft.				
What is the nearest source of possible contamination:				
1 Septic tank	4 Lateral lines	7 Pit privy	<u>10 Livestock pens</u>	14 Abandoned water well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
Direction from well? <u>on every side</u>				

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	4	Topsoil			
4	15	Brown clay			
15	70	Brown sandy clay			
70	150	Med. sand + brown clay			
150	166	White clay layers			
166	174	White clay			
174	200	Med. sand + brown clay layers			
200	204	Brown clay			
204	206	Med. sand			
206	230	Brown clay			
230	315	Coarse sand			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1) constructed</u> (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>10-13-93</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>533</u> This Water Well Record was completed on (mo/day/yr) <u>10-25-93</u> under the business name of <u>Jantzen Water Well Repair</u> by (signature) <u>[Signature]</u>
--