


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 25	Township number T 27 S R 29	Range number E/W
2. Distance and direction from nearest town or city: 10 S. & 1 E. of Ingalls Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code: Harriet Wulfemeyer 6 Detroit St. Hutchinson, KS 67501		
4. Locate, with "X" in section below: Sketch map: N  W E S 1 Mile 1 Mile	Well drilled 5-19-76		6. Bore hole dia. 26 in. Completion date 5-24-76 Well depth 245 ft.		
5. Type and color of material See attachment	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 245 ft. depth Wall Thickness: <input type="checkbox"/> in. Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .250		
			10. Screen: Manufacturer's name Johnson Type <input checked="" type="checkbox"/> Continuous Dia. 16" Slot/gauze 150 Length 50 Set between 130 ft. and 180 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/4 <input checked="" type="checkbox"/> 1/8		
			11. Static water level: 71 ft. below land surface Date 5-24-76		
			12. Pumping level below land surfaces: 110 ft. after <input type="checkbox"/> hrs. pumping 1400 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: <input type="checkbox"/> observed ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: Flat	19. Remarks: (Use a second sheet if needed)	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilg. & Supply 145 Business name <input type="checkbox"/> License No. Address <input type="checkbox"/> Box 639 Garden City KS Signed <input type="checkbox"/> Date 6-10-76 Authorized representative			

DRILLERS TEST LOG

CUSTOMERS NAME Carri-Monkey → Harriet Wulfmeyer DATE 5-15-76
 STREET ADDRESS _____ TEST # 3 E. Log
 CITY & STATE Montezuma, KS DRILLER Schiffman
 COUNTY Gray QUARTER W SECTION 25 TOWNSHIP 27 RANGE 22

LOCATION 100' north and 30' west of the southeast corner of the north-west 1/4

WELL LOCATION

%	DRILLED FOOTAGE			Description of Strata	Static Water Level	Proposed Well Depth
	From	Pay	To			
	0		2	Top soil		
	2		9	Brown sandy clay		
	9		13	Fine sand		
	13		51	Brown sandy clay and caliche		
	51		63	Yellow clay		
	63		100	Sand fine to med. coarse, small, med. to large gravel		
70	100	42	142	Sand fine to med. coarse, small to med. gravel, clay st., few large gravel, used water from 63' to 187'		
65	142	45	187	Sand fine to med. coarse, small to med. gravel, few large gravel, few white rock and few clay st. Brown clay		
	187		200	Brown sandy clay and lime rock		
	200		219	Yellow sandy clay		
50	222	9	231	Sand fine to med. coarse		
	231		235	Sandy clay and fine sand		
45	235	5	240	Sand fine to small, few coarse		
	240		256	Brown sandy clay		
	256		269	Clay, broken rock, soapstone		
	101					

WELL DEPTH 245'

SET RIG EAST

PIT MOUTH