


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction 	Section number 27	Township number T 27 S	Range number R 29 S/W
2. Distance and direction from nearest town or city:			3. Owner of well: Ralph Fry		
Street address of well location if in city:			R.R. or street: Montezuma, Ks 67867		
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. <u>26</u> in. Completion date <u>5-13-76</u> Well depth <u>319</u> ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input type="checkbox"/> Steel <input type="checkbox"/> Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>320</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>ft.</u> depth gage No. <u>16</u>		
			10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>270-280</u> ft. and <u>300-310</u> Perf. <u>120-270</u> ft. and <u>280-300</u> , <u>300-310</u> Gravel pack? <u>yes</u> Size range of material <u>11" down</u>		
			11. Static water level: <u>78</u> ft. below land surface Date <u>2-13-76</u>		
			12. Pumping level below land surfaces: <u>90</u> ft. after <u>2</u> hrs. pumping <u>825</u> g.p.m. <u>98</u> ft. after <u>7</u> hrs. pumping <u>1100</u> g.p.m. Estimated maximum yield <u>1400</u> g.p.m.		
			13. Water sample submitted: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u>2-13-76</u>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: <u>N/A</u> ft. <u>0</u> Direction <u>0</u> Type <u>0</u> Well disinfected upon completion? <u>Yes</u> <input checked="" type="checkbox"/> <u>No</u> <input type="checkbox"/>		
			17. Pump: Manufacturer's name <u>Peerless</u> Not installed Model number <u>12LB</u> HP <u>100</u> Volts <u>1100</u> Length of drop pipe <u>140</u> ft. capacity <u>120</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			18. Elevation:	19. Remarks:	
			Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter Wilson Drilling 208</u> Business name <u>Winter Wilson Drilling 208</u> License No. <u>14</u> Address <u>P.O. Box A Garden City, KS</u> Signed <u>Winter Wilson</u> Date <u>7/16/76</u> Authorized representative <u>Winter Wilson</u>	

Business **MINTER-WILSON DRILLING CO.** INCORPORATED Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 273-8229 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Ralph Fry (owner)
Earl Koehn (tenant)
Gray County
8-15-75

Location: North of pivot to north side of $\frac{1}{4}$ SW $\frac{1}{4}$ 27-27-29

Test #6

0	1	Top soil
1	6	Sand & clay mixed
6	53	Brown clay
53	69	Brown clay & white rock (tight)
69	80	Fine to med. sand & gravel, 15% clay (loose)
80	147	Fine to med. sand & gravel (loose)
147	155	Brown clay & white rock
155	185	Fine to med. sand & fine gravel (loose)
185	198	Brown sandy clay
198	237	Fine to med. sand & fine gravel, 10% clay (loose)
237	248	Brown sandy clay
248	260	Fine to med. sand & fine gravel, 15% clay (loose)
260	282	Fine to med. sand & fine gravel (loose)
282	295	Brown sandy clay
295	319	Fine to med. sand & gravel with brown rock (loose)
319	331	Brown, gray & yellow clay (hard)
331	335	Shale (hard)

Static Water Level: 80

T.D. - 319'