

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 29	Township number 27	Range number R 29	EW
2. Distance and direction from nearest town or city: south of Peirceville 15 miles 9 east 1 3/4 north 1/4 west Street address of well location if in city:			13 1/2 miles R.R. or street: City, state, zip code: Montezuma, Ks. 67867	Daniel Unruh		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 7-19-76 Well depth 289 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <input type="checkbox"/> steel <input type="checkbox"/> iron Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 16 PWS <input type="checkbox"/> Weight 36.8 lbs./ft. Dia. 16 in. to 280 ft. depth Wall Thickness: inches or Dia. 16 in. to 280 ft. depth gage No.		
5. Type and color of material		From	To	10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Division Type <input type="checkbox"/> G <input checked="" type="checkbox"/> I <input type="checkbox"/> V <input type="checkbox"/> Dia. 16" Slot/gauze 100 Length 20' Set between 260 ft. and 280 ft. Pori. 100-170 ft. and 216-260-280-289 Gravel pack? <input type="checkbox"/> yes Size range of material 16" Depth		
				11. Static water level: mo./day/yr. 81 ft. below land surface Date 7-9-76		
				12. Pumping level below land surfaces: 96 ft. after 3 hrs. pumping 1500 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1500 g.p.m.		
				13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: <input type="checkbox"/> N/A ft. Direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds US Pumps Model number 12JTC HP 125 Volts Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kinter Wilson Drilling 208 Business name <input type="checkbox"/> P.O. Box A Garden City, KS Address <input type="checkbox"/> Signature <input type="checkbox"/> Date 9-22-76 Signed <input type="checkbox"/> Authorized representative		
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MINTER-WILSON DRILLING CO. INCORPORATED Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

D.W.U.U.
Gray County
6-1-76

Locations NW 29-27-29 Pivot of NW 1/4 Str. 101 From Schilling-4
Miles 1 1/4 Miles South 1/4 Lat.
Static Water Level- 90'

Test #1

0	3	Top Soil
3	70	Fine Sand
34	63	Tim and white Clay
63	134	Fine To Med. Sand and Gravel (Med. Coarse) Loose
134	136	Caliche and Tim and white Clay
160	167	Fine To Med. Sand Loose
167	191	Sandy Tim Clay
171	206	Sugar Sand and Tim Clay Shds 20/4 No Good
206	216	Sandy Tim Clay
216	289	Fine To Med. Coarse sand and Gravel Loose
289	305	Shale

10 289
Screen

Best Available Copy