


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction <i>N 1/2 NE NW 1/4 NE 1/4</i>	Section number	Township number	Range number
	Gray	SE 1/4	31	T 27	S R 29 E 1/4
2. Distance and direction from nearest town or city: 4 north, 4 1/2 west, and 1/2 north of Montezuma Street address of well location if in city:	3. Owner of well: Paul Yost R.R. or street: RFD City, state, zip code: Montezuma, Kansas 67867				
4. Locate with "X" in section below:	Sketch map: 				
5. Type and color of material	From	To	6. Bore hole dia. 9 7/8 in. Completion date Well depth 352 ft. 7-08-77		
Top Soil	0	5	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Fine sand	5	51	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine sand with clay	51	70	9. Casing: Material <input checked="" type="checkbox"/> PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 352 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. .265		
Med. sand with some clay streaks	70	103	10. Screen: Manufacturer's name <input checked="" type="checkbox"/> Jess & Lowell Type <input checked="" type="checkbox"/> PVC Dia. 5" Slot/gauge 1/8" Length 80' Set between 232 ft. and 352 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material #1 fine		
Med. to lar. sand & gravel with clay	103	195	11. Static water level: mo./day/yr. 132 ft. below land surface Date 6/30/77		
Clay with sandy streaks	195	300	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Med. to lar. sand & Gravel	300	360	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Rock		360	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Unit Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
			16. Nearest source of possible contamination: ft. 100 Direction west Type feed lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name <input checked="" type="checkbox"/> Aermotor Model number SD12 HP 1 Volts 220 Length of drop pipe 126 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name <input type="checkbox"/> Meade, Kansas 67864 License No. Address <input type="checkbox"/> Signed <i>J. Friesen</i> Date 8-9-77 Authorized representative					