


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

*Test*  
#4  
WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction SW 1/4 NE 1/4 SE 1/4	Section number 34	Township number 1 27	Range number S R 29	<i>E/W</i>		
2. Distance and direction from nearest town or city: Street address or well location if in city:	south of Ingalls to the 22 mile road 2 1/2 west 3/8 north 3/8 east					3. Owner of well: Harold Kochn R.R. or street: Montezuma, Ks. 67867 City, state, zip code:		
4. Locate with "X" in section below:	Sketch map:					6. Bore hole dia. <u>26</u> in. Completion date <u>2-29-76</u> Well depth <u>212</u> ft.		
						7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
			9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <u>16</u> PVC <u>16</u> Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>214</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>214</u> ft. depth gage No. <u>16</u>					
			10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Gely</u> Dia. <u>16</u> in. Slot/gauze <u>100</u> Length <u>20</u> ft. Set between <u>210</u> ft. and <u>230</u> ft. Port. <u>130-210</u> ft. and <u>230-243</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1-2</u> in. <u>Bottom</u>					
			11. Static water level: <u>106</u> ft. <u>2 mo./day/ft.</u> ft. below land surface Date <u>2-29-76</u>					
			12. Pumping level below land surfaces: <u>200</u> ft. after <u>3</u> hrs. pumping <u>250</u> g.p.m. <u>200</u> ft. after <u>5</u> hrs. pumping <u>250</u> g.p.m. Estimated maximum yield <u>250</u> g.p.m.					
			13. Water sample submitted: <u>mo./day/yr.</u> <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>2-29-76</u>					
			14. Well head completion: <u>Pitless adapter</u> <u>12</u> inches above grade					
			15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.					
			16. Nearest source of possible contamination: ft. <u>100</u> Direction <u>SW</u> Type <u>Waste</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>W.W. Wilson</u> Model number <u>100</u> HP <u>1</u> Volts <u>110</u> Length of drop pipe <u>10</u> ft. capacity <u>100</u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)						18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>W.W. Wilson Drilling Co.</i> Business name P.O. Box 1 Garden City, Ks. Address <u>100 S. Main St. Garden City, Ks.</u> Signed <u>W.W. Wilson</u> Date <u>1-76</u> Authorized representative <u>W.W. Wilson</u>