


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 8	Township number T 27 S R 29	Range number W	
2. Distance and direction from nearest town or city: 8 south, 1 east, 3 south, 2 east, 1/4 south, 1/4 west of Charleston.		3. Owner of well: Paul Yost R.R. or street: Montezuma, Ks. 67867 City, state, zip code:				
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: 		6. Bore hole dia. 26 in. Completion date 10-16-76 Well depth 210 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above at base Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 211 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
				10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20 ft. Set between 180 ft. and 200 ft. Perf: 120-180 ft. and 200-210 ft. Gravel pack? yes Size range of material 1/2" down		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 67 ft. below land surface Date 9-17-76		
				12. Pumping level below land surfaces: 116 ft. after 3 hrs. pumping 1100 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1100 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - US Pump Model number 12 JHC HP 100 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity 1100 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name Box A Garden City, Ks. License No. <input type="checkbox"/> Address Box A Garden City, Ks. Signed [Signature] Date 5-20-76 Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5



MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

PAUL YOST
(ROY YOST)
GRAY COUNTY
3-10-76

Location: NE 1/4 S-27-29 form Lloyd Fracks house first road south
south 2 miles west 1/4 mile south 1/4 miles west at pin
Static Water Level- 80'

Test #1

0	1	Top soil
1	3	Fine sand
3	46	Brown sandy clay & fine sand
46	163	Fine to med. sand and gravel Loose
163	185	Fine to med. sand and gravel skts. of clay 10%
185	210	Fine to med. sand and gravel skts. of clay and brown rock 10% Loose
210	223	Brown and yellow clay hard used pull down
223	230	Shale

T.D. 210