

CORRECTION TO WATER WELL RECORD (WWC-5)

The following correction(s) was made to the attached WWC-5 log, in order to file the item or to rectify lacking or incorrect information.

Fraction (1/4 1/4 1/4) Section-Township-Range changed:

listed as SE SW NE, 14-105-32W

changed to SE SW NE, 31-275-3W

Other changes: Initial statements: _____

Changed to: _____

Comments: _____

verification method: Well address on form, position on plat map, and

Garden Plain 1:24,000 topo. map.

initials: DRS date: 7/18/2000

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment Bureau of Water Industrial Programs, Bldg 283, Forbes Field, KS 66620

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>SEDGWICK</u>		<u>SE 1/4 SW 1/4 NE 1/4</u>	<u>14</u>	<u>T 10 S</u>	<u>R 32 E</u>
Distance and direction from nearest town or city street address of well if located within city?					
<u>OBW-1</u>					
2 WATER WELL OWNER: <u>FARMERS COOP ELEVATOR</u>					
RR#, St. Address, Box #: <u>410 NORTH MAIN</u>				Board of Agriculture, Division of Water Resources	
City, State, ZIP Code: <u>GARDEN PLAIN, KS 67050</u>				Application Number:	
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>15</u> ft. ELEVATION:			
		Depth(s) Groundwater Encountered 1. <u>10.5</u> ft. 2. _____ ft. 3. _____ ft.			
		WELL'S STATIC WATER LEVEL <u>10.58</u> ft. below land surface measured on mo/day/yr <u>4/26/00</u>			
		Pump test data: Well water was _____ ft. after _____ hours pumping _____ gpm			
		Est. Yield _____ gpm: Well water was _____ ft. after _____ hours pumping _____ gpm			
		Bore Hole Diameter <u>8</u> in. to <u>1.5</u> ft., and _____ in. to _____ ft.			
		WELL WATER TO BE USED AS:			
		5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only <u>10 Monitoring well</u>			
		Was a chemical/bacteriological sample submitted to Department? Yes _____ No <u>X</u> ; If yes, mo/day/yr sample was submitted _____			
		Water Well Disinfected? Yes _____ No <u>X</u>			
5 TYPE OF BLANK CASING USED:					
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued _____ Clamped _____ <u>2 PVC</u> <u>4 ABS</u> 6 Asbestos-Cement 9 Other (specify below) Welded _____ Blank casing diameter <u>2</u> in. to <u>5</u> ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft. Casing height above land surface <u>FLUSH</u> in., weight _____ lbs./ft. Wall thickness or gauge No. <u>SC-40</u>					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) _____ SCREEN OR PERFORATION OPENINGS ARE: 5 Gauzed wrapped <u>8 Saw cut</u> 11 None (open hole) 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify) _____					
SCREEN-PERFORATED INTERVALS: From <u>5</u> ft. to <u>15</u> ft., From _____ ft. to _____ ft.					
GRAVEL PACK INTERVALS: From <u>3</u> ft. to <u>15</u> ft., From _____ ft. to _____ ft.					
6 GROUT MATERIAL: 1 Neat cement <u>2 Cement grout</u> <u>3 Bentonite</u> 4 Other _____					
Grout Intervals: From <u>0</u> ft. to <u>1</u> ft., From <u>1</u> ft. to <u>3</u> ft., From _____ ft. to _____ ft.					
What is the nearest source of possible contamination:					
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon <u>11 Fuel storage</u> 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) _____ 13 Insecticide storage					
Direction from well? _____ How many feet? _____					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>6"</u>	<u>CONCRETE</u>			
<u>6"</u>	<u>3.5</u>	<u>SILTY CLAY, BROWN</u>			
<u>3</u>	<u>10</u>	<u>SILTY CLAY, RED BROWN</u>			
		<u>SLIGHT INCREASE IN SILT W/DEPTH</u>			
<u>10</u>	<u>15</u>	<u>SILTY CLAY, OLIVE GREEN</u>			
		<u>TO SANDY CLAY, OLIVE GREEN</u>			
<u>TD = 15</u>					
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1)</u> constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>4/17/00</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>6608</u> This Water Well Record was completed on (mo/day/yr) <u>5/31/00</u> under the business name of <u>EGE</u> by (signature) <u>[Signature]</u>					