



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Sedgwick</u>	Fraction <u>SE 1/4 SW 1/4 NE 1/4</u>	Section number <u>12</u>	Township number <u>27</u>	Range number <u>3</u>
2. Distance and direction from nearest town or city:		3. Owner of well: <u>Kenneth Kruse</u>		R.R. or street: <u>21821 Argosia Ct.</u>		
Street address of well location if in city: <u>1909 Paul End Rd Goodland KS</u>		City, state, zip code: <u>Goodland KS 67052</u>				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>6</u> in. Completion date <u>3/30/78</u>		
				Well depth <u>26</u> ft.		
5. Type and color of material		From		To		7. Cable tool ☒ Rotary ☐ Driven ☐ Dug
<u>Top soil.</u>		<u>0.8</u>				☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary
<u>Brown red clay.</u>		<u>8.26</u>				8. Use: ☒ Domestic ☐ Public supply ☐ Industry
<u>Blue green shale</u>		<u>26</u>		<u>40</u>		☐ Irrigation ☐ Air conditioning ☐ Stock
<u>Charcoal shale</u>		<u>40</u>		<u>80</u>		☐ Lawn ☐ Oil field water ☐ Other
						9. Casing: Material <u>Styrene</u> Height <u>12</u> Above or below
						Threaded ☐ Welded ☒ Surface <u>12</u> in.
						RMP <u>5</u> PVC <u>1.50</u> Weight <u>1.50</u> lbs./ft.
						Dia. <u>5</u> in. to <u>80</u> ft. depth Wall Thickness: inches or
						Dia. <u>5</u> in. to <u>80</u> ft. depth gage No. <u>200</u>
						10. Screen: Manufacturer's name <u>Sunflower</u>
						Type <u>200</u> Dia. <u>5</u> in.
						Set between <u>30</u> ft. and <u>80</u> ft.
						Gravel pack? <u>Yes</u> Size range of material <u>3/8</u>
						11. Static water level: <u>11</u> ft. below land surface Date <u>3/30/78</u>
						12. Pumping level below land surfaces:
						<u>40</u> ft. after <u>1/2</u> hrs. pumping <u>15</u> g.p.m.
						<u>40</u> ft. after <u>1</u> hrs. pumping <u>15</u> g.p.m.
						Estimated maximum yield <u>25</u> g.p.m.
						13. Water sample submitted: <u>Yes</u> ☒ No ☐ Date <u>3/30/78</u>
						14. Well head completion: <u>12</u> inches above grade
						<u>Pitless adapter</u>
						15. Well grouted? <u>Yes</u>
						With: <u>Neat cement</u> ☐ Bentonite ☒ Concrete ☐
						Depth: From <u>3</u> ft. to <u>12</u> ft.
						16. Nearest source of possible contamination: <u>300</u> ft. Direction <u>E</u> Type <u>Creek</u>
						Well disinfected upon completion? ☒ Yes ☐ No
						17. Pump: ☒ Not installed
						Manufacturer's name <u>Wagner</u>
						Model number <u>318</u> HP <u>3</u> Volts <u>115</u>
						Length of drop pipe <u>318</u> ft. capacity <u>3</u> g.p.m.
						Type: ☐ Submersible ☐ Turbine
						☐ Jet ☐ Reciprocating
						☐ Centrifugal ☐ Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: ☒ Hill ☐ Slope ☐ Upland ☐ Valley				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
				Business name <u>Wagner, Kelly</u> License No. <u>318</u>		
				Address <u>318</u>		
				Signed <u>Wagner, Kelly</u> Date <u>3/30/78</u>		
				Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5