

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction SW 1/4 SE 1/4 SE 1/4	Section number 10	Township number T 27 S	Range number R 30 E/W	
2. Distance and direction from nearest town or city: 2 1/2 E 10 N of Copeland	3. Owner of well: Merle FRAZER					
Street address of well location if in city: Copeland, Kansas 67837						
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 8/9/78 Well depth 200 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input checked="" type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Cast iron Height: Above or below Threaded <input type="checkbox"/> Welded gl Surface 14 in. RMP 5 PVC 1 Weight 100 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. 5 in. to 140 ft. depth gage No. 0.258		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Peerless		
Overburden		0	90'	Type PVC Dia. 5 in.		
Clay with Coarse SAND streaks		90'	125'	Slot/gauze 1/16 Length 60'		
SAND + GRAVEL		125'	200'	Set between 140 ft. and 200 ft.		
				Gravel pack? Yes Size range of material 7/8		
				11. Static water level: 90 ft. below land surface Date 8/9/78		
				12. Pumping level below land surfaces:		
				ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
				13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 8/9/78		
				14. Well head completion: 14 inches above grade Pitless adapter		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
				16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ITW Waterwell Service 142 Model number 142 HP 1 Volts 115 Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible Turbine <input type="checkbox"/> Jet Reciprocating <input type="checkbox"/> Centrifugal Other		
		(Use a second sheet if needed)		18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. ITW Waterwell Service 142 Business name Box 816 Liberal, KS. License No. Address 11th & Main Date 1978 Signed John Doe Authorized representative		
		17. Well to be completed by: Dunham Drilling Co. Copeland Kansas 67837				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5