

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

2730 W 12 WEWEWE
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bdg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name Ingalls	Fraction NE$\frac{1}{4}$	Section number #12	Town number T #27	Range number R #30
Distance and direction from nearest town or city: 8 south and 4 miles west of Ingalls Street address of well location if in city:			3 Owner of well: Ben H. Koehn Address: Ingalls, Kansas 67853			
<p>Locate with "X" in section below:</p> <p>Sketch map: NE$\frac{1}{4}$ of the NE$\frac{1}{4}$ of the NE$\frac{1}{4}$ of Section #12 T #27 R #30</p>						
4	Well depth: 262 ft. Date of completion 7-17-75			Well diameter 8 in.		
5	<input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
6	Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well					
7	Casing: Material RMP Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 in. to 262 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth					
8	Screen: Manufacturer Sunflower Type RMP Dia. 5" S/gauze 1/8" Length 20 ft. Set between 220 ft. and 260 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4"					
9	Static water level: 79 ft. below land surface Date 7-17-75					
10	Pumping level below land surfaces: 90 ft. after 2 hrs. pumping 125 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 175 g.p.m.					
11	Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____					
12	Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 <input type="checkbox"/> Inches above grade					
13	Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite _____ Depth: From 10 ft. to 25 ft.					
14	Nearest source of possible contamination: ft. 120 Direction South Type sewer system Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
15	Pump: <input type="checkbox"/> Not installed Manufacturer's name Flint & Walling Model number 10BK9 HP 1 Volts 230 Length of drop pipe 147 ft. capacity 19 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
16	Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					
17	Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name _____ License No. _____ Address Box 174 Cimarron, Ks. Signed Joe's Crick Date 9-4-91 Authorized representative					

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

Topography:
 Hill
 Slope
 Upland
 Valley

Business name Box 174 Cimarron, Ks. License No. 9-4-75
Address
Signed Fay Clegg Date 9-4-75
Authorized representative