

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 NW 1/4 SW 1/4	Section number #28	Township number T #27	Range number S R #30	W
2. Distance and direction from nearest town or city:	8 1/2 miles north, 1 mile east and 1/2 mile north of Copeland, Kansas		3. Owner of well: Carl Mackey			
Street address of well location if in city:		R.R. or street: City, state, zip code: Montezuma, Kansas 67867				
4. Locate with "X" in section below:	Sketch map: 		Sketch map:	6. Bore hole dia. 8 in. Completion date Well depth 365 ft. 2-16-76		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material RMP Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight lbs./ft. Dia. 5 in. to 365 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 250		
5. Type and color of material	From	To	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Slot <input type="checkbox"/> 1/8" Length 20 ft. Set between 340 ft. and 360 ft. ft. and ft. Gravel pack? yes Size range of material 1/4"			
Top soil, clay & fine sand	0	15	11. Static water level: 120 ft. below land surface Date 2-16-76 mo./day/yr.			
Fine sand	15	30	12. Pumping level below land surfaces: 125 ft. after 2 hrs. pumping 30 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 60 g.p.m.			
Fine sand & clay	30	45	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date			
Clay & fine sand	45	60	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade			
Fine sand	60	90	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 20 ft.			
Fine to medium sand	90	105	16. Nearest source of possible contamination: None ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Medium to coarse sand	105	120	17. Pump: Not installed Manufacturer's name Flint & Walling Model number 7BA12 HP 3/4 Volts 230 Length of drop pipe 210 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Coarse sand	120	165	18. Elevation: 19. Remarks: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			
Coarse sand & clay	165	195				
Clay	195	210				
Clay & fine sand layers	210	225				
Clay	225	240				
Clay & fine sand layers	240	255				
Clay	255	300				
Clay & medium sand	300	315				
Medium to coarse sand	315	330				
Coarse sand (Use a second sheet if needed)	330	375				
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name License No. Address Box 174 Cimarron, Ks. Signed <i>Joe's Well Service</i> 5-25-85 Date Authorized representative						