

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Gray</b>	Fraction <b>NW 1/4 SE 1/4 SE 1/4</b>	Section number <b>33</b>	Township number <b>T 27 S R 30 E</b>	Range number <b>30</b>
2. Distance and direction from nearest town or city: <b>7 1/2 mile North and 2 mile East of Copeland</b>				3. Owner of well: <b>William Beck</b>		
Street address of well location if in city:				City, state, zip code: <b>Copeland, Kansas 67837</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. _____ in. Completion date <b>8-16-76</b> Well depth <b>383</b> ft.		
				7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored _____ <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: _____ Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____		
5. Type and color of material		From		To		9. Casing: Material <b>steel</b> Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface <b>12"</b> in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. _____ in. to _____ ft. depth Wall Thickness _____ inches or Dia. _____ in. to _____ ft. depth gage No. <b>8</b>
						10. Screen: Manufacturer's name _____ <b>W. A. Brown Ent.</b> Type <b>Bridge</b> Dia. <b>16"</b> Slot/gauze <b>Slot</b> Length <b>2"</b> Set between <b>283</b> ft. and <b>383</b> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>5/8</b>
Top soil & clay		0		15		11. Static water level: <b>8-16-76</b> mo./day/yr. <b>140</b> ft. below land surface Date _____
Clay & little fine sand		15		30		12. Pumping level below land surfaces: _____ ft. after <b>5</b> hrs. pumping <b>1280</b> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>1800</b> g.p.m.
Clay & Fine sand		30		45		
Clay, little lime & fine sand		45		90		13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
Clay & sand		90		105		
Sand, & Gravel		105		137		14. Well head completion: _____ Pitless adapter <b>12</b> Inches above grade
Clay & little lime		137		140		
sand, & little cemented sand		140		163		15. Well grouted? <b>yes</b> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From <b>0</b> ft. to <b>10</b> ft.
Hard lime & clay		163		166		
Sand, little cemented sand, little hard & clay		166		180		16. Nearest source of possible contamination: <b>None</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____
Sand		180		187		
Clay		187		192		17. Pump: _____ Not installed Manufacturer's name <b>Layne</b> Model number <b>1976</b> HP <b>125</b> Volts _____ Length of drop pipe <b>220</b> ft. capacity _____ g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____
Sand		192		210		
Clay		210		217		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Dunham Drilling Co.</b> <b>223</b> Business name _____ License No. _____ Address <b>Copeland, Kansas 67837</b> Signed <b>[Signature]</b> date <b>10-29-76</b> Authorized representative
Clay		217		229		
Sand		229		237		(Use a second sheet if needed)
Clay		237		262		
Hard lime & little clay		262		266		18. Elevation:
Clay & fine sand		266		278		
Clay		278		349		19. Remarks: <b>Land machine leveled</b>
Good Coarse sand		349		383		
Clay		383		400		Topography: _____ Hill _____ Slope _____ Upland _____ Valley
Sandstone		400		420		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5