


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 35	Township number T 27	Range number S R 30	W
2. Distance and direction from nearest town or city: Copeland 3 1/4 east 1/2 north Street address of well location if in city:	3. Owner of well: Jack Ullom R.R. or street: Montezuma, Ks. 67867 City, state, zip code:					
4. Locate with "X" in section below: 	Sketch map:			6. Bore hole dia. 26 in. Completion date 6-17-76 Well depth 353 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <input type="checkbox"/> steel <input type="checkbox"/> iron <input type="checkbox"/> aluminum Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.8 lbs./ft. Dia. 16 in. to 27 ft. depth <input type="checkbox"/> Wall thickness: inches or Dia. 16 in. to 27 ft. depth <input type="checkbox"/> gage No. <input type="checkbox"/>			
			10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Division Type <input type="checkbox"/> Galv. <input type="checkbox"/> Dia. 16" Slot/gauze 100 <input type="checkbox"/> Length 20' Set between 280-290 ft. and 330-340 ft. Pump 140-280 ft. and 290-330-340 ft. <input type="checkbox"/> 330 ft. Gravel pack? <input type="checkbox"/> Yes <input type="checkbox"/> Size range of material <input type="checkbox"/> 11 Diam.			
			11. Static water level: <input type="checkbox"/> mo./day/yr. 100 ft. below land surface Date 6-7-76			
			12. Pumping level below land surfaces: 2650 ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> 2650 g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <input type="checkbox"/> 0 ft. to <input type="checkbox"/> 10 ft.			
			16. Nearest source of possible contamination: <input type="checkbox"/> N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			17. Pump: <input type="checkbox"/> Goules <input checked="" type="checkbox"/> New installed Manufacturer's name <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> Model number <input type="checkbox"/> 14JIC HP 200 Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> 200 ft. capacity <input type="checkbox"/> 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hinter Wilson Drilling 208 Business name P.O. Box A Garden City, KS 67050 Address <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> Signed <input type="checkbox"/> Date <input type="checkbox"/> Authorized representative <input type="checkbox"/>			
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals **MINTER-WILSON DRILLING CO.**
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Jack Ullom
Gray County
4-1-76

Location: 200 ft. east of NW corner of quarter or $\frac{1}{4}$ mile
west of test #1 NE $\frac{1}{4}$ 35-27-30

Test 2

0	4	Top soil
4	36	Brown sandy clay
36	43	Fine sand
43	63	Brown sandy clay
63	94	Fine sand, streaks of clay (20%) small hard streaks
94	143	Fine to med. sand & gravel (loose)
143	152	Fine to med. sand & gravel, streaks of clay (20%)
152	170	Brown sandy clay
170	185	Fine to med. sand & gravel (loose)
185	201	Fine to med. sand, streaks of clay (10%)
201	214	Fine to med. sand & fine gravel (loose)
214	231	Brown & white sandy clay
231	240	Brown & white sandy clay, small streaks of fine sand
240	277	Fine sand, streak of clay (20%) tight
277	294	Fine to med. sand (loose)
294	316	Fine to med. sand, streaks of clay (10%) loose
316	319	Brown sandy clay
319	353	Fine to med. sand & gravel (loose)
353	365	Brown, yellow, gray, white clay (hard used pull down)

Static Water Level: 97'

2.0. - 353 MAX