

T	R	EW	sec	1/4	1/4	1/4	No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

Perforations: 240-200, 210-215, 225-230

Gravel pack ☒ Yes ☐ No Size range of material _____

9 Static water level:
81 ft. below land surface Date 5-19-75

10 Pumping level below land surfaces:
96 ft. after 2 hrs. pumping 663 g.p.m.
106 ft. after 4 hrs. pumping 1110 g.p.m.
Estimated maximum yield 1100 g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date _____

12 Well head completion:
☐ Pitless adapter 12 Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ Neat cement ☐ Bentonite ☐ _____
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination: N/A
ft. _____ Direction _____ Type _____
Well disinfected upon completion? ☐ Yes ☒ No

15 Pump: ☐ Not installed
Manufacturer's name Peerless-FMC
Model number 4606 HP 100 Volts _____
Length of drop pipe 140 ft. capacity 800 g.m.p.
Type:
☐ Submersible ☒ Turbine
☐ Jet ☐ Reciprocating
☐ Centrifugal ☐ Other

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Minter-Wilson Drilling. 208
Business name Box 493 Garden City, Ms.
Address
Signed [Signature] Date 5-20-75
Authorized representative

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Haskell County

Ed Hesser

March 18, 1975

S $\frac{1}{4}$ sec. 2 T. 27 R. 31 Static Water Level 96 Test # 1 Pivot

Location: 11 miles South of Pierceville, $\frac{1}{2}$ East, $\frac{1}{2}$ North
Test

0	2	Top Soil
2	34	Brown Clay
34	80	Fine to Medium Sand & Gravel (Loose) streaks of Coarse Gravel
80	97	Brown Clay
97	125	Fine to Medium Sand & Gravel 10% Clay (Loose)
125	137	Brown Sandy Clay
137	170	Fine to Medium Sand & Gravel (Loose)
170	192	Brown Sandy Clay
192	200	Fine to Medium Sand & Gravel 10% Clay (Loose)
200	210	Fine to Medium Sand & Gravel (Loose)
210	215	Brown Sandy Clay
215	230	Fine to Medium Sand & Gravel 10% Clay (Loose)
230	302	Brown Sandy Clay
302	320	Brown Sandy Clay, streaks of Fine to Medium Sand & Fine Gravel 30%

TD 230' Screen 20'