


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HASKELL	Fraction SE 1/4 NW 1/4 SE 1/4	Section number 4	Township number T 27 S	Range number R 31 E
2. Distance and direction from nearest town or city: 2 south 1 west 3/4 north 1/2 west of county line south of Pierceville			3. Owner of well: Bob Messerly R.R. or street: 302 Franklin City, state, zip code: Sublette, Ks. 67877		
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 6-24-76 Well depth 335 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 336 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
			10. Screens: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 260-270 ft. and 310-320 ft. Perf. 120-260 ft. and 270-310 ft. 320' Gravel pack? yes Size range of material 3/4" Down		
			11. Static water level: 86 ft. below land surface Date 5-18-76 mo./day/yr.		
			12. Pumping level below land surfaces: 100 ft. after 3 hrs. pumping 1100 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1100 g.p.m.		
			13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
			14. Well head completion: 12 <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> yes Inches above grade		
			15. Well grouted? <input type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name FMC Peerless Pump Model number 12MB HP 125 Volts Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business Box 1 Address Box A Garden City, Mo. Signature <i>[Signature]</i> Date 5-19-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The
Professionals*

MINTER-WILSON DRILLING CO. Complete Installation and Repairing
INCORPORATED

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

BOB HISSERLY
HASKELL COUNTY
3-25-76

LOCATION: SEC 4-27-31
South Of Pierceville To County Line, 2
Miles South, 1 Mile West, 1 1/2 Mile North,
1/2 Mile West, 30 Feet West Of

STATIC WATER LEVEL: 80'

TEST #2

0	2	Top Soil
2	12	Brown Sandy Clay
19	100	Fine To Med. Sand & Gravel (Loose)
100	150	Fine To Med. Sand & Gravel Streaks Of Clay (10%)
150	200	Fine To Med. Sand & Gravel (Loose)
200	270	Fine To Med. Sand, Streak Of Clay (10%) Loose
270	310	Brown Sandy Clay, Streak Of Fine To Med. Sand (20%)
310	335	Fine To Med. Sand, Streak Of Clay (10%) (Loose)
335	350	Brown Sandy Clay, Yellow & Gray Clay
350	355	Shale