

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 25	Township number T 27	Range number S R 31 E/W
2. Distance and direction from nearest town or city: 1/4 N 1 W 7/2 N of Copeland, KS. Street address of well location if in city:			3. Owner of well: Marvin Koehn R.R. or street: City, state, zip code: Copeland, Kansas 67870		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 5 in. Completion date _____ Well depth 250 ft. 5/12/76	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 200 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0.320	
Overburden		0	139	10. Screen: Manufacturer's name _____ J+L Type PVC Dia. 5" Slot/gauze 1/4" Length 50" Set between 200 ft. and 250 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/8"	
Coarse Sand + Clay streaks		139	170	11. Static water level: _____ mo./day/yr. 139 ft. below land surface Date 5/12/76	
Sand, Gravel + Clay streaks		170	240	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ 60 g.p.m.	
Sand Stone + Shale		240	250	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 14 Inches above grade	
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
				16. Nearest source of possible contamination: ft. 150 Direction SE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks: Well to be Completed by: Dunham Drilling Copeland, KS			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+W Water Well 142 Business name _____ License No. _____ Address Box 816 Liberal, KS Signed [Signature] Date 5/12/76 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 27
 R 31
 E/W
 Sec 25
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5