


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell County	Fraction 1/4 1/4 CNW 1/4	Section number 28	Township number T 27 S	Range number R 31 E/W
2. Distance and direction from nearest town or city: On the North edge of Sublette 1 1/2 West, 11 North on 83, 8 East, 1 3/4 North, 1/2 East			Owner of well: Henry Nightengale R.R. or street: Sublette, KS 67877 City, state, zip code:		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	
Casing Schedule					
0 - 200 Plain					
200 - 250 Perf.					
250 - 270 Screen					
270 - 340 Perf.					
340 - 360 Screen					
360 - 470 Perf.					
470 - 490 Screen					
490 - 495 Perf.					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		6. Bore hole dia. 26 in. Completion date 7-29-79 Well depth 495 ft.		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 495 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
			10. Screen: Manufacturer's name Johnson Type Johnson Galv. dia. 100-16" Slot/gauze <input type="checkbox"/> length <input type="checkbox"/> ft. between <input type="checkbox"/> and <input type="checkbox"/> ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/2 to 5/8		
			11. Static water level: 147 ft. below land surface Date 2-22-79 mo./day/yr.		
			12. Pumping level below land surfaces: 156 ft. after 2 hrs. pumping 1200 g.p.m. 158 ft. after 4 hrs. pumping 1500 g.p.m. Estimated maximum yield 1500 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 14" 4 stg. Bowl Model number <input type="checkbox"/> HP 200 Volts <input type="checkbox"/> Length of drop pipe 260 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drlg. Co. 208 Business name License No. Address Box A, Garden City, KS 67846 Signed <i>[Signature]</i> Date 2/27/79 Authorized representative		

27 310 28 1/4 C NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67840

November 10, 1977

**Henry Nightengale
Haskell County**

Location: NW $\frac{1}{4}$ 28-31-27 from Country Store 2 West, $\frac{1}{2}$ South,
20' East

Static Water Level - 130

Lat #

0	6	Top Soil
6	76	Brown Clay
16	274	Fine to med. sand & gravel
274	279	Brown Sandy Clay
279	360	Fine to med. sand & gravel 10% Clay
360	381	Fine to med. sand & gravel 15% Clay (tight)
381	470	Brown Sandy Clay
470	490	Fine to med. sand & gravel mixed with brown yellow rock
490	512	Brown Clay
512		

T. D. 495