

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>WASKELL</b>	Fraction <b>SE 1/4 NE 1/4 SW 1/4</b>	Section number <b>2</b>	Township number <b>T 27 S R 31</b>	Range number <b>31</b> <i>W</i>
2. Distance and direction from nearest town or city: <b>15 miles south of Pioncville, 1 west 1/2 north</b> Street address of well location if in city:			3. Owner of well: <b>Alice Yost</b> R.R. or street: <b>Montezuma, Ks. 67867</b> City, state, zip code:		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <b>26</b> in. Completion date <b>5-31-76</b> Well depth <b>280</b> ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material <b>steel</b> Height: Above or Below <b>MISS</b> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>22</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <b>1250 MAC</b>		
			10. Screen: Manufacturer's name <b>JOHNSON DIVISION</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauze <b>100</b> Length <b>20'</b> Set between <b>330</b> ft. and <b>350</b> ft. <del>Perforated 190-215 ft. and 280-320, 350-400</del> Gravel pack? <input type="checkbox"/> Size range of material <input type="checkbox"/>		
			11. Static water level: <b>195</b> ft. below land surface Date <b>5-15-76</b> mo./day/yr.		
			12. Pumping level below land surfaces: <b>1225</b> <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>1225</b> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <b>12</b> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
			15. Well grouted? <b>YES</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
			16. Nearest source of possible contamination: <input type="checkbox"/> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <b>Not installed</b> Manufacturer's name <b>Goulet US Pumps</b> Model number <b>12J10</b> HP <b>100</b> Volts <input type="checkbox"/> Length of drop pipe <b>280</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Winter Wilson Drilling 208</b> Business name <b>Box A Gordon City, Mo.</b> Address <b>_____</b> Signed <b>[Signature]</b> Date <b>9-1-76</b> Authorized representative		
19. Remarks:					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

27 3 10 E  
 R  
 3 2 SW NE SW  
 1/4 1/4  
 Sec

The Professionals

# MINTER-WILSON DRILLING CO.

INCORPORATED

Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

ALICE YOUST  
HASKELL COUNTY  
1-27-76

Location Sw 32-27-31  
From Salem Menonite Church, South of Pierce-  
ville, 1 Mile West, 850 Feet North, 20 Ft. East

Static Water Level 165'

Test #2

0	3	Top Soil
3	34	Brown Sandy Clay
34	50	Fine Sand & Clay Mixture (50%) No Good
50	81	Fine Sand (No Good)
81	99	Brown Sandy Clay
99	188	Fine To Med Sand & Gravel (Loose)
188	200	Brown Sandy Clay
200	219	Fine To Med. Sand & Gravel (Loose)
219	231	Fine To Med. Sand & Gravel, Streaks of Clay (10%)
231	277	Fine To Med. Sand & Gravel (Loose)
277	310	Fine To Med. Sand, Streaks of Clay (20%) No Good
310	368	Fine Sand & Blue Clay Mixture (50%) No Good
368	388	Fine To Med. Sand & Gravel, Streaks of Clay (10%) Tight
388	395	Brown Sandy Clay & Gray Clay, Streaks Of Fine To Med. Sand & Gravel (25%)