

289

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 33	Township number T 27 S R	Range number E/W 31
2. Distance and direction from nearest town or city: From Pierceville, Kansas go 14 south and 1 1/2 west.			3. Owner of well: Orlan Wedel R.R. or street: R. R. 1, Box 61A City, state, zip code: Copeland, KS 67837			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date _____ Well depth <u>412</u> ft. <u>10-31-78</u>		
		<p>Near the NE corner of the NW 1/4, Sec. 33, T27S, R31W, Haskell County, Kansas.</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	2	9. Casing: Material <u>Stl</u> Height: Above or below		
Brown clay		2	21	Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>12</u> in.		
Fine sand with clay streaks, tight		21	64	RMP _____ PVC _____ Weight <u>37</u> lbs./ft.		
Brown clay		64	82	Dia. <u>16</u> in. to <u>212</u> ft. depth Wall Thickness: inches or		
Fine sand		82	102	Dia. _____ in. to _____ ft. depth gage No. <u>.219</u>		
Brown clay		102	132	10. Screen: Manufacturer's name <u>Foster, Cook,</u>		
Fine to medium sand, clean and loose		132	150	<u>Doerr</u>		
Medium to coarse sand, loose		150	200	Type <u>M/S, W/W, Louver</u> <u>16"</u>		
Medium to coarse sand and fine gravel, loose		200	250	Slot/gauze <u>1/8"</u> Length <u>200'</u>		
Fine to medium sand with few clay streaks		250	280	Set between <u>212</u> ft. and <u>412</u> ft.		
Brown clay, tight		280	300	_____ ft. and _____ ft.		
Medium to coarse sand, loose		300	352	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>4.2 mm</u>		
Brown clay with sand streaks		352	384	11. Static water level: _____ mo./day/yr.		
Medium to coarse sand, loose		384	412	<u>206</u> ft. below land surface Date <u>10-5-78</u>		
Sandy brown clay		412	430	12. Pumping level below land surfaces:		
Fine to medium sand with clay streaks, light		430	466	<u>232</u> ft. after <u>1</u> hrs. pumping <u>1921</u> g.p.m.		
Brown clay with sand streaks		466	480	_____ ft. after _____ hrs. pumping _____ g.p.m.		
Black shale		480	520	Estimated maximum yield <u>2000</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr.		
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion:		
				<input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <u>Yes</u>		
				With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>Unknown</u>		
				ft. _____ Direction _____ Type _____		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed		
				Manufacturer's name <u>WellLine</u>		
				Model number <u>12THC</u> HP <u>136</u> Volts _____		
				Length of drop pipe <u>300</u> ft. capacity <u>2000</u> g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography:		Replacement well.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Hill				Layne-Western Co., Inc. 102		
<input type="checkbox"/> Slope				Business name _____ License No. _____		
<input checked="" type="checkbox"/> Upland				Address <u>Garden City, KS 67846</u>		
<input type="checkbox"/> Valley				Signed <u>Steve Ferguson</u> Date <u>1-24</u>		
				Authorized representative		

27
 31
 33
 NE
 NE
 NW
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5