

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction NW 1/4 NE 1/4	Section number 36	Township number T 27	Range number S R 31
2. Distance and direction from nearest town or city: 8 miles North 1 1/2 Mile West				3. Owner of well: Don Moore R.R. or street: City, state, zip code: Copeland, Kansas 67837		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 2 1/2" in. Completion date 5-17-76 Well depth 320 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation Air conditioning <input type="checkbox"/> Stock Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 320 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 7		
0 15 Top soil & clay				10. Screen: Manufacturer's name W. A. Brown Ent.		
Clay		15	30	Type Bridge Dia. 16" Slot/gauze slot 2" Length 2' / 00" Set between 220 ft. and 320 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/8		
Clay & little Fine Sand		30	97	11. Static water level: 110 ft. below land surface Date 5-17-76		
Clay & cemented sand		97	105	12. Pumping level below land surfaces: Not test		
Clay, fine sand & little cemented sand		105	120	_____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Clay & 1' sand		120	135	13. Water sample submitted: _____ mo./day/yr.		
Sand		135	150	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Sand, gravel & little cemented sand		150	165	14. Well head completion: _____		
Coarse Sand		165	179	Pitless adapter 12 Inches above grade		
Clay		179	180	15. Well grouted? Yes		
Coarse sand & 1' clay		180	195	With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.		
Sand & 3' Clay		195	210	16. Nearest source of possible contamination: None		
Sand		210	225	ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sand & 1' clay		225	238	17. Pump: _____ Not installed		
Cemented Sand		238	240	Manufacturer's name Layne Model number 1976 HP 150 Volts _____ Length of drop pipe 220 ft. capacity 2000 g.p.m.		
Coarse sand & little cemented sand		240	262	Type: _____ <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other		
Lime & Hard Clay (Use a second sheet if needed)		262	270	20. Water well contractor's certification:		
Clay & Lime (Very Hard)		270	281	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Sand		281	316	Dunham Drilling co. 223 Business name License No.		
Clay & Little Lime		316	330	Address Copeland, Kansas Signed [Signature] Date 7-2-		
Topography: _____ Hill <input checked="" type="checkbox"/> Slope _____ Upland _____ Valley		Machine Levelled.				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

27 316 36 NE 1/4
 Sec 1/4 1/4 1/4