


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HASKELL	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 2	Township number T 27 S	Range number R 32 E
2. Distance and direction from nearest town or city: 11 studio south fo Garden City, on Hiway 83		Owner of well: Naomia Pontius R.R. or street: 206 W 27th City, state, zip code: Hutchinson, ks. 67501			
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 26 in. Completion date 5-31-76 Well depth 122 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material steel Height: Above of below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 123 depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 280 MNC	
				10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 280 ft. and 300 ft. Peri. 260-280 ft. and 300-422 ft. Gravel pack? yes Size range of material 1/2" Down	
				11. Static water level: <input type="checkbox"/> mo./day/yr. 132 ft. below land surface Date 4-12-76	
				12. Pumping level below land surfaces: 185 ft. after 2 hrs. pumping 800 g.p.m. 181 ft. after 4 hrs. pumping 1275 g.p.m. Estimated maximum yield 1275 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. N/A	
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Customer Firinished his own old pump				
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 203 Business name P.O. Box A Garden City, ks Address 16-7-74 Signed Minter Wilson Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Ref. 10/16

MINTER-WILSON DRILLING CO.
INCORPORATED

and Domestic
Water Systems
• Complete Installation
and Repairing

Phone 276-8269

• P.O. Box 493

• GARDEN CITY, KANSAS 67846

DON LEAR (TENANT)

Naomwz ~~HOME~~ PONTIUS (OWNER)

HASKELL COUNTY

3-5-78

LOCATION: HWY 2-27-32

1 1/2 Mile South, 3/8 Mile East Of D. Lear
House

STATIC WATER LEVEL: 105

TEST #1

0	1	Top Soil
1	38	Brown Clay
38	47	Brown Clay (3%) Gravel
47	91	Med. To Coarse Gravel (Loose)
91	110	Brown Clay
110	163	Fine To Med. Sand & Gravel (Loose)
163	174	Brown Clay
174	260	Blue Clay
260	275	Fine To Med. Sand & Gravel (10%) Clay (Loose)
275	309	Fine To Med. Sand & Gravel (Loose)
309	327	Fine To Med. Sand & Gravel (10%) Clay (Loose)
327	343	Brown Sandy Clay
343	365	Fine To Med. Sand & Gravel (10%) Clay (Loose)
365	395	Brown Sandy Clay
395	422	Fine To Med. Sand & Fine Gravel (10%) Clay (Loose)
422	438	Brown & Gray Clay
488	450	Brown, Gray & Yellow Clay (Hd)

50
~~440~~