


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HASKELL	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 3	Township number T 27 S	Range number R 32 E
2. Distance and direction from nearest town or city: 3 east, 1 1/2 north of Georgetown			Owner of well: Bob Nightengale R.R. or street: Copland, KS 67837 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 12-28-76 Well depth 383 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From		To		9. Casing: Material steel Height: above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 384 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250
				10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16 in. Slot/gauge <input type="checkbox"/> Length 20 ft. Set between 350 ft. and 370 ft. Perf: 160-350 ft. and 370-383 ft. Gravel pack? yes Size range of material 1/2" down		
				11. Static water level: 120 ft. below land surface Date 12-23-76 mo./day/yr.		
				12. Pumping level below land surfaces: 151 ft. after 2 hrs. pumping 950 g.p.m. 171 ft. after 4 hrs. pumping 1500 g.p.m. Estimated maximum yield 1500 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds-US Pump Model number 14 JMC HP 200 Volts <input type="checkbox"/> Length of drop pipe 280 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. Address Box A Garden City, Ks. Signed [Signature] Date 5-13 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Check Loc.

Bob Wightengale
Haskell County
5-22-76

Location: From Georgetown, 3 miles East, 1 1/2 mile north,
east side of road SW 3-27-32

Test #1

0	4	Top soil
4	12	Brown clay
12	40	Brown sandy clay
40	50	Fine to med. sand
50	160	Fine to med. sand & gravel (loose)
160	183	Fine to med. sand & gravel, streaks of clay (20%) tight
183	200	Fine to med. sand & gravel, streak of clay (10%) lo loose
200	231	Fine to med. sand, streak of clay (10%) loose
231	245	Fine to med. sand, streak of clay (15%)
245	274	Fine to med. sand & gravel, small streak of clay (10%) loose
274	320	Fine to med. sand & gravel (loose)
320	350	Fine to med. sand & gravel, streak of clay (10%)
350	383	Fine to med. sand & gravel (loose)
383	395	Brown sandy clay, fine to med. sand mixture (50%) no good
395	450	Fine sand & clay mixture (tight) no good
450	468	Brown, yellow, gray clay (hard used pull down)
468	470	Shale

Static Water Level: 115

TD - 383'