


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HASKELL	Fraction SW 1/4 SE 1/4 NW 1/4	Section number 5	Township number T 27 S	Range number R 32 E/W
2. Distance and direction from nearest town or city: South of Garden City, Kas. 11 Highway 113-1 east Street address of well location if in city: 1 E Sublette on 83-14 S			3. Owner of well: Max Davis R.R. or street: S Star Route City, state, zip code: Garden City, Kas. 67846			
4. Locate with "X" in section below: 			Sketch map:		6. Bore hole dia. 26 in. Completion date 5-31-76 Well depth 215 ft.	
5. Type and color of material			From		To	
7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
9. Casing: Material steel Height: Above MLC Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 22.07 lbs./ft. Dia. 6 5/8 in. to 216 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 250mm			10. Screen: Manufacturer's name No Screen Type <input type="checkbox"/> Dia. <input type="checkbox"/> Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Between 32 ft. to bottom yes ft. and 12 ft. Gravel pack? <input type="checkbox"/> Size range of material <input type="checkbox"/>			
			11. Static water level: 110 ft. below land surface Date 5-5-75 mo./day/yr.			
			12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.			
			13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.			
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
			15. Well grout: 8 With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Goulds US Pumps Model number 25TL HP 1 1/2 Volts <input type="checkbox"/> Length of drop pipe 147 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)						
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter Wilson Drilling 208 Business name P.O. Box 1 Garden City, Kas. Address 9-22-76 Signed [Signature] Date 9-22-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

and Domestic
Water Systems
Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

MAX DAVIS
Haskell County
5-5-75

Location: South of Garden City to Haskell county line,
1 mile east, south side of road NW 1/4 5-27-32

0	2	Top soil
2	37	Brown clay
37	66	Fine to med. sand and gravel (loose)
66	85	Med. to coarse gravel (loose)
85	97	Brown sandy clay, streaks of gravel, 30%
97	149	Fine to med. sand and gravel (loose)
149	173	Brown clay and white rock (hard)
173	210	Fine to med. sand and gravel (loose)
210	215	Brown sandy clay

Static water level: 110'

T.D. 215'