


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 6	Township number T 27 S	Range number R 32 E
2. Distance and direction from nearest town or city: Approximately 9 1/2 miles SW of Pierceville, Ks. Street address of well location if in city:			3. Owner of well: Forrest & Kenneth Cox R.R. or street: C/O Forrest Cox City, state, zip code: Sublette, Kansas 67877		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 2/27/79 Well depth 473 ft.
See Attachment					7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.92 lbs./ft. Dia. 16 in. to 473 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
					10. Screen: Manufacturer's name W. A. Brown Type Louvered Dia. 16 " Slot/gauze .100 Length 130 " Set between 278 ft. and 298 ft. 318 - 418 ft. and 438 - 448 ft. Gravel pack? Yes Size range of material #1 Fine & #1 Coarse
					11. Static water level: 134 ft. below land surface Date 2/28/79 mo./day/yr.
					12. Pumping level below land surfaces: 177 ft. after <input type="checkbox"/> hrs. pumping 1457 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1,500 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.
					14. Well head completion: Pitless adapter 12 Inches above grade
					15. Well grouted? Yes With: Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: x Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: (Use a second sheet if needed)		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & SPLY 145 Business name License No. Address Box 639, Garden City, Ks Signed Bruce J. Reichmuth Date 3/2/79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Forrest and Kenneth Cox DATE 2/9/79
 STREET ADDRESS _____ TEST # 3 E. LOG Yes
 CITY & STATE Sublette, Kansas DRILLER Livingston
 COUNTY Haskell QUARTER SE SECTION 6 TOWNSHIP 27 RANGE 32
 LOCATION NW corner of the SE $\frac{1}{4}$.

%	FOOTAGE			DESCRIPTION OF STRATA	NEW WELL LOCATION	
	From	Pay	To		Static Water Level _____	Proposed Well Depth _____
	0		3	Top Soil		
	3		47	Clay, gyprock and a few sand sts.		
	47		86	Sand fine to med with small to large gravel.		
	86		125	Sand fine to med coarse, small gravel with a few limerock ledges.		
	125		140	Brown clay		
55	140	17	157	Sand fine to med coarse and small gravel.		
	157		173	Brown clay with limerock ledges.		
	173		180	Blue clay		
	180		191	Brown sandy clay, limerock ledges with a few sand sts.		
65	191	09	200	Sand fine to med coarse, small to med size gravel.		
	200		210	Brown sandy clay, limerock ledges with a few sand sts.		
	210		224	Blue clay		
	224		231	Brown sandy clay with limerock ledges.		
25	231	29	260	Brown sandy clay, sand fine to med coarse with small gravel sts.		
	260		270	Brown sandy clay		
25	270	50	320	Sand fine to med coarse, small to med size gravel with cemented ledges.		
	320		324	Brown sandy clay and limerock.		
50	324	06	330	Sand fine to med coarse with a few small gravel.		
	330		340	Brown sandy clay		
50	340	12	352	Sand fine to med coarse with a few small gravel.		
	352		360	Brown sandy clay		
50	360	05	365	Sand fine to med coarse.		
	365		393	Brown clay		
30	393	06	399	Sand fine to med/small. Loose.		
	399		410	Limerock, chalk and clay.		
	410		440	Tan clay - sticky		
50	440	13	453	Sand fine to med with a few coarse.		
Good	453	17	470	Sandstone - Used alot of water.		
	470		480	Limestone, soapstone and shale.		
			164			
				TOTAL DEPTH OF WELL 473'		
				Set up facing South		
				Dig pit on the North		
				Note: Move Location of Well 5' West of Test Hole #3.		

GARDEN CITY, KS
 Phone 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
 IRRIGATION HEADQUARTERS

SUBLETTE, KS
 Phone 675-4311

TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * STOCK WELLS