WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction	-	Section	number	Township number	Range number		
1. Location of well:	Haskell	5/2 1/4 SW 1/4 NT	J ^{1/4}	7	,	T 27 S	R 32	E/W	
2. Distance and direction from nearest town or city: 16 mi. N of 3. Owner of						of well: Leonard Rogge Estate			
Street address of well	location if in city:	onnie L. Rogge							
4. Locate with "X" in section below: Sketch map:						Garden City, Kansas 67846 6. Bore hole dia. 28 in. Completion dat 7/22/76			
N I						Well depth 420 ft.			
600' E of the SW corner of the						7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored 🗶 Reverse rotary			
MW 4, Sec. 7, T27S, R32W, Haskell County, Kansas.						8. Use: Domestic Public supply Industry X			
	Threaded Welded Surface 12 in. RMP PVC Weight 37_lbs./ft.								
1 Mile ————————————————————————————————————						Dia. 16 in. to 160 ft. dep	h Wall Thickness: inc	ches or	
5. Type and color of	material			From	То	Dia in. to ft. dept 10. Screen: Manufacturer's n			
Top soil					2	Typelouver, mils			
•					<u></u>	Slot/gauze 1/811 Length 2601			
Fine sand					31	Set betweenft. a		ft.	
Fine to c	darse sand med.	ravel tan clay	, stk	31	53	Gravel pack? yes Size ran		4mm	
Coarse sand and gravel small rock				53	160	 Static water level: 110ft. below land sur 		/day/yr. /76	
Tan chay gravel streaks				160	165	12. Pumping level below land			
Medium to coarse gravel				165	192	135 ft. after hrs. pumping 1837 g.p.m. 145 ft. after hrs. pumping 2412 g.p.m.			
				1		Estimated maximum yieldg.p.m. 13. Water sample submitted:mo./day/yr.			
Tan clay gravel straaks				192		Yes X No Date			
Medium to coarse gravel				221	258	14. Well head completion: Pitless adapter X Inches above grade			
Sand and gravel blue clay streaks					319	15. Well grouted? yes	110100 0000	P	
Fine to coarse sand med. gravel with						With: Neat cement X Depth: From O ft. to		Concrete -	
light tan clay streaks				319	379	16. Nearest source of possible contamination: unk.			
						ft Direction Well disinfected upon comple	42	No1(_,	
Fine to coarse sand medium gravel				379	500	17. Pump:	Not installed	— <u>™</u>	
						Manufacturer's name Lass Model number 12 TL	HP Vol	™ — V `	
						Length of drop pipe 300 Type:	_ ft. capacity 140	Q.p.m. 8	
						Type: Submersible	X Turbine	1. [
(Use a second sheet if needed)						Jet Centrifugal	Recipro	cating S	
18. Elevation: 19. Remarks: 20. Water well contractor's certification:									
						This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Topography: Hill						Layne-Western	Co., Inc.	102 5	
Slope						Business name Address Garden Ci	Kansas	ense No.	
X Upland Valley		Signed Authorized repr	esentative / Share	12 15 N					