

USE TYPEWRITER OR BALL
POINT - ~~IN PRESS~~ FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Haskell		Fraction Center of SE 1/4		Section number 17		Township number 27		Range number 32		E (W)	
1. Location of well:						3. Owner of well: J. Greer Thompson					
2. Distance and direction from nearest town or city: 17 3/4 S. & 1 3/4 E. of						R.R. or street: 4220 Virginia Vista					
Street address of well location if in city: Garden City						City, state, zip code: Long Beach, CA					
4. Locate with "X" in section below:						6. Bore hole dia. 26 in. Completion date 6-11-76					
Sketch map: Well drilled 6-8-76 						Well depth 480 ft.					
						7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary <input type="checkbox"/>					
5. Type and color of material						8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>					
						9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 480 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219					
See attachment						10. Screen: Manufacturer's name Brown					
						Type Louvered Dia. 16" Slot/gauze 1/8" Length 80" Set between 365 ft. and 285 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4 x 1/2					
						11. Static water level: <input type="checkbox"/> mo./day/yr. 126 ft. below land surface Date 6-11-76					
						12. Pumping level below land surfaces: 161 ft. after <input type="checkbox"/> hrs. pumping 1404 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.					
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>					
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade					
						15. Well grouted? Yes <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.					
						16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>					
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other <input type="checkbox"/>					
(Use a second sheet if needed)											
18. Elevation: Flat						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 639 Garden City, TX Signed E. L. B. [Signature] Date 6-29-76 Authorized representative					
19. Remarks:											
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley											

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME J. Greer Thompson DATE 5-28-76
STREET ADDRESS _____ TEST # 1 E. Log 500'
CITY & STATE Long Beach, CA DRILLER Rector
COUNTY Haskell QUARTER SE SECTION 17 TOWNSHIP 27 RANGE 32

LOCATION Center of 1/4 and 18 ft. SE of pivot

WELL LOCATION					
%	DRILLED		FOOTAGE	Description of Strata	Static Water Level
	From	Pay To			Proposed Well Depth
	0		5	Sand	
	5		25	Brown clay	
	25		47	Brown sandy clay	
55	47	15	165	Sand fine med. coarse, small gravel, few large, and very fine clay st. (loose)	
	165		182	Brown clay, lime rock, ledges, & embedded sts. of sand & gravel	
65	182	18	210	Sand fine med. coarse, small gravel, loose, used water	
	210		220	Brown clay and sts. of sand	
	220		236	Blue clay	
30	236	4	240	Sand fine to med.	
	240		294	Blue clay and few rock ledges and few sand sts.	
70	294	26	320	Sand fine med. coarse, small gravel (loose) ragged, used water, mud heavy	
65	320	49	369	Sand and gravel fine, med., med. small, small gravel few clay and lime rock sts., used lots of water, mud heavy	
	369		430	Brown clay and lime rock	
Fair	430	10	440	Brown clay, fine sand and sts. of brown rock, used water	
Fair	440	16	456	Yellow clay, soapstone and brown sandstone, used little water	
	456		464	Shale and bauxite sts.	
Good	464	14	478	Brown sandstone and yellow sandy clay, very hard ledge at 478'	
	478		500	Gray and blue shale (firm)	
		152			
TOTAL DEPTH OF WELL 480 ft.					
Set up face east					
Pit on south					

ARDEN CITY, KANSAS
PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
PHONE 675-4311

EST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****