


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | |
|---|--------------------------|---|--|----------------------------------|-------------------------------|
| 1. Location of well: | County Haskell | Fraction XX XX NE 1/4 | Section number 20 | Township number T 27 S | Range number R 32 E |
| 2. Distance and direction from nearest town or city: 14 N. of Sublette Street address of well location if in city: | | | 3. Owner of well: J. Greer Thompson R.R. or street: 4220 Virginia Vista City, state, zip code: Long Beach, CA | | |
| 4. Locate with "X" in section below: N W E S 1 Mile Sketch map:  | | | 6. Bore hole dia. 26 in. Completion date 8-5-76 Well depth 497 ft. | | |
| 5. Type and color of material See attachment | | | 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary | | |
| | | | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | | |
| | | | 9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 497 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219 | | |
| | | | 10. Screen: Manufacturer's name Brown Type Louvered Dia. 16" Slot/gauze: 080 & .125 Length 207 Set between 497-420 ft. and 385-285 ft. 265-235 ft. and <input type="checkbox"/> ft. Gravel pack <input checked="" type="checkbox"/> Yes Size range of material 1/4 x 1/8 | | |
| | | | 11. Static water level: <input type="checkbox"/> mo./day/yr. 152 ft. below land surface Date 8-5-76 | | |
| (Use a second sheet if needed) | | | 12. Pumping level below land surfaces: 168 ft. after <input type="checkbox"/> hrs. pumping 1404 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m. | | |
| | | | 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> | | |
| | | | 14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade | | |
| | | | 15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. | | |
| | | | 16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | |
| 18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | | | 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| | | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name License No. <input type="checkbox"/> Address Box 639 Garden City, KS Signed E. L. Bothwell Date 8-12-76 Authorized representative | | |
| | | | 19. Remarks: | | |
| | | | | | |
| | | | | | |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME J. Greer Thompson DATE July 8, 1976
 STREET ADDRESS _____ TEST # 1 E. Log 500 ft.
 CITY & STATE Long Beach, CA DRILLER Rector
 COUNTY Haskell QUARTER NE SECTION 20 TOWNSHIP 27 RANGE 32

LOCATION Center of 1/4 & 20' NW of pivot

WELL LOCATION

| % | DRILLED | | FOOTAGE | Description of Strata | Static Water Level |
|-----------|---------|--------|---------|---|--------------------|
| | From | Pay To | | | Proposed Well |
| | 0 | | 4 | Surface | |
| | 4 | | 33 | Brown sandy clay and fine sand | |
| | 33 | | 40 | Sand | |
| | 40 | | 57 | Brown clay, caliche and fine sand | |
| 50 | 57 | 15 | 195 | Sand and gravel, used lots of water, mud heavy | |
| | 195 | | 205 | Brown sandy clay and fine sand | |
| | 205 | | 235 | Brown clay and sand sts. and few small ledges | |
| 65 | 235 | 23 | 258 | Sand fine med. coarse and small gravel (very good) | |
| | 258 | | 280 | Blue clay, lime rock sts. and sand sts. | |
| | 280 | | 288 | Sandy blue clay and fine sand | |
| 60 | 288 | 9 | 297 | Sand fine med. coarse and small gravel, loose, used water | |
| 55 | 297 | 33 | 330 | Sand fine med. coarse, small gravel, very fine sandy clay, used water | |
| 65 | 330 | 18 | 340 | Sand fine med. coarse, small gravel, loose, used lots of water | |
| | 340 | | 350 | Brown clay and lime rock and sand | |
| 60 | 350 | 10 | 360 | Sand fine med. coarse and small gravel | |
| | 360 | | 372 | Brown clay and lime rock | |
| 60 | 372 | 11 | 383 | Sand fine med. coarse and small gravel | |
| | 383 | | 412 | Brown clay and lime rock | |
| 65 | 412 | 2 | 414 | Brown rock and brown sandstone, used lots of water | |
| | 414 | | 420 | Yellow clay and soapstone | |
| Fair | 420 | 6 | 426 | Brown sandstone, soapstone and st. of red shale | |
| Very Good | 426 | 34 | 460 | Brown sandstone and shale, used lots of water | |
| Good | 460 | 12 | 472 | Sandstone and shale (hard) | |
| | 472 | | 480 | Shale and soapstone | |
| Good | 480 | 15 | 495 | Brown sandstone and shale | |
| | 495 | | 500 | Blue shale | |
| | | 188 | | | |
| | | | | TOTAL DEPTH OF WELL 497 FT. | |
| | | | | Set up southeast | |
| | | | | Pit on west | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

RDEN CITY, KANSAS
 ONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
 IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
 PHONE 675-4011

3T HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****