

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | |
|---|-----------------------|--|--|---------------------------------|----------------------------|
| 1. Location of well: | County Haskell | Fraction NE 1/4 SW 1/4 NE 1/4 | Section number 34 | Township number T 27 S R | Range number 32 4/W |
| 2. Distance and direction from nearest town or city: 22 miles south of Garden City, 4 east | | | 3. Owner of well: Arlin Yost | | |
| Street address of well location if in city: 1 north, 500' west | | | R.R. or street: Sublette, Ks. 67877 | | |
| 4. Locate with "X" in section below: Sketch map: | | | 6. Bore hole dia 26 in. Completion date 6-15-76 | | |
| | | | Well depth 418 ft. | | |
| | | | 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary | | |
| 5. Type and color of material | | | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | | |
| | | | 9. Casing: Material steel Height: Above ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 419 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/> | | |
| | | | 10. Screen: Manufacturer's name Johnson | | |
| | | | Type Galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20' Set between 378-388 ft. and 403-413 ft. Perf-200-378 ft. and 388-403, 413-418 Gravel pack? yes Size range of material 1/2" down | | |
| | | | 11. Static water level: <input type="checkbox"/> mo./day/yr. 174 ft. below land surface Date 6-10-76 | | |
| | | | 12. Pumping level below land surfaces: 210 ft. after 3 hrs. pumping 1450 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1450 g.p.m. | | |
| | | | 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> | | |
| | | | 14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade | | |
| | | | 15. Well grouted? yes With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. | | |
| | | | 16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | |
| | | | 17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds-US Pump Model number 14JHC HP 200 Volts <input type="checkbox"/> Length of drop pipe 340 ft. capacity 1400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| | | | (Use a second sheet if needed) | | |
| 18. Elevation: | | 19. Remarks: | | | |
| Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. <input type="checkbox"/> Address Box A Garden City, Ks. Signed <i>[Signature]</i> Date 12-29-76 Authorized representative | | | |

27 32 34
1/4 NE SW NE
1/4 SW NE
1/4 SW NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professionals

MINTER-WILSON DRILLING CO.

Water Systems
Complete Installation
and Repairing

INCORPORATED

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

WELL YORK
Jaskill County
5-24-76

Location: 1/4 34-27-32 20' below surface of ground
and 500' to west

Static Water Level-155

Test

| | | | |
|-----|-----|---------------------------------------|-----|
| 0 | 3 | Top Soil | |
| 3 | 102 | Sandy Tan Clay | |
| 102 | 239 | Med. To Coarse Sand and Gravel | |
| 239 | 286 | Sandy Tan Clay | |
| 286 | 336 | Fine To Med. Sand and Gravel Tan Clay | 10' |
| 336 | 364 | Sandy Tan Clay | |
| 364 | 372 | Fine To Med. Sand and Gravel Tan Clay | 10' |
| 372 | 378 | Sandy Tan Clay | |
| 378 | 392 | Fine To Med. Sand and Gravel | |
| 392 | 403 | Tan Clay | |
| 403 | 416 | Fine To Med. Sand and Gravel | |
| 416 | 458 | Tan and Blue Clay | |
| 458 | 460 | Shale | |

TO 416

Screen 20