

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County <b>Haskell County</b>		Fraction <b>1/4 SW 1/4 NW 1/4</b>		Section number <b>6</b>	Township number <b>T 27 S</b>	Range number <b>R 33 W</b>
2. Distance and direction from nearest town or city: <b>6 West, 3 South, 1/2 East.</b>			3. Owner of well: <b>Fern Batchelder</b>			
Street address of well location if in city: <b>1/2 South, 1/2 West of TV 11</b>			R.R. or street: <b>1706 B</b>			
			City, state, zip code: <b>Garden City, KS 67846</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>4-29-79</b>		
				Well depth <b>364</b> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>364</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>.219</b>		
5. Type and color of material		From	To	10. Screen: Manufacturer's name <b>Johnson</b>		
				Type <b>Johnson Galv.</b> Dia. <b>100-16"</b>		
				Slot/gauze <b>0-180 Plain</b> and <b>180-230 Perf.</b>		
				Set between <b>230-260 Plain</b> and <b>260-280 Perf.</b>		
				<b>280-300 Screen</b> and <b>300-364 Perf.</b> ft.		
				Gravel pack? <b>yes</b> Size range of material <b>1/2 to 5/8</b>		
				11. Static water level: <input type="checkbox"/> mo./day/yr. <b>139</b> ft. below land surface Date <b>4-17-79</b>		
				12. Pumping level below land surfaces: <b>153</b> ft. after <b>2</b> hrs. pumping <b>1200</b> g.p.m. <b>156</b> ft. after <b>4</b> hrs. pumping <b>1500</b> g.p.m. Estimated maximum yield <b>1500</b> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>1 ft.</b> Inches above grade		
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <b>N/A</b> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b> Gould 6 stg. 12 JHC Bowl</b> Model number <input type="checkbox"/> HP <b>125</b> Volts <input type="checkbox"/> Length of drop pipe <b>220</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling Co. 208</b> Business name License No. Address <b>Box A, Garden City, KS 67846</b> Signed <i>[Signature]</i> Date <b>4/27/79</b> Authorized representative			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

# WINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

March 1, 1979

Fern Batchelder  
Haskell County

Location: NW $\frac{1}{4}$  6-27-33 Offset 300' West of Pivot

Static Water Level - 140

Test #A

	18	Top Soil
18	62	Brown Clay
62	96	Med. coarse gravel (loose)
96	123	Coarse gravel (loose)
123	135	Fine to med. sand and gravel (loose)
135	167	Med. coarse gravel
167	173	Brown Sandy Clay
173	198	Fine to med. sand and gravel streak of med. coarse gravel (loose)
198	217	Brown Sandy Clay
217	228	Fine to med. sand and gravel 10% Clay (loose)
228	254	Yellow Gray Black Clay
254	261	Blue Clay
261	266	Fine to med. sand and gravel
266	274	Blue Clay
274	309	Fine to med. sand and gravel streak of med. coarse gravel
309	327	Fine to med. sand and gravel streak of med. coarse gravel hard streak
327	341	Brown Sandy Clay (hard)
341	357	Fine to med. sand and gravel tight 10% Clay
357	364	Fine to med. sand and fine gravel
364	382	Brown Sandy Clay
382	425	Brown Sandy Clay White Rock hard

T. D. 364'