

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell County	Fraction 1/4 1/4 SW 1/4	Section number 6	Township number T 27 S	Range number R 33 E/W
2. Distance and direction from nearest town or city: 1 1/2 West of Sublette, 16 North on Hiway 83, 5 3/4 West, 1/4 North Street address of well location if in city:			Owner of well: Fern Batchelder R.R. or street: 1706 B City, state, zip code: Garden City, KS 67846		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. 26 in. Completion date 6-30-79 Well depth 385 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 385 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
			10. Screen: Manufacturer's name Johnson Type Johnson Galv. Dia. 100-16" Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/2 to 5/8		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 130 ft. below land surface Date 5-8-79		
			12. Pumping level below land surfaces: 150 ft. after 2 hrs. pumping 1000 g.p.m. 167 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 1200 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 6 stg. 12" JHC Model number <input type="checkbox"/> HP 125 Volts <input type="checkbox"/> Length of drop pipe 220 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. <input type="checkbox"/> Address Box A, Garden City, KS 67846 Signed <i>[Signature]</i> Date 8-17-79 Authorized representative		

2733 Bowl 10 1/4 CSW

WINTER WILSON DRILLING CO. Complete Installation
and Repairing
INCORPORATED

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67840

May 8, 1979

Fern Batchelder
Haskell County

Location: SW $\frac{1}{4}$ 6-27-33
Static Water Level - 130
Test #4 Pivot

0	1	Top Soil
1	6	Fine Sand
6	11	Brown Clay
11	52	Fine Sand
52	65	Brown Sandy Clay
65	78	Fine to med. sand and gravel
78	110	Med. coarse gravel
110	122	Med. coarse gravel 10% Clay
122	183	Med. coarse gravel
183	199	Gray White Clay
199	226	Blue Clay hard streak
226	231	Brown Clay
231	243	Fine to med. sand and gravel hard streak 15% Clay
243	262	Brown Clay
262	276	Gray Blue Clay Small streak of gravel
276	309	Fine to med. sand and gravel streak of med. coarse and hard streak
309	315	Brown Sandy Clay hard
315	342	Fine to med. sand and gravel (loose)
342	354	Brown Sandy Clay hard
354	380	Fine to med. sand and gravel
380	390	Brown Sandy Clay
390	402	Brown Sandy Clay White Rock mixed
402	420	Yellow Clay Brown Rock hard

T. D. 385'