



**DRILLERS TEST LOG**

**CUSTOMERS NAME** Master Land **DATE** April 20, 1981  
**STREET ADDRESS** Box 1054 **TEST #** 1 **E. LOG** Yes  
**CITY & STATE** Garden City, Ks. 67846 **DRILLER** Mai  
**COUNTY** Haskell **QUARTER** NW **SECTION** 10 **TOWNSHIP** 27 **RANGE** 33

**LOCATION** South East of Morton Bldg. & Headquarters. **WELL LOCATION** \_\_\_\_\_

%	FOOTAGE			DESCRIPTION OF STRATA	Static Water Level _____
	From	Pay	To		Proposed Well Depth <u>348'</u>
	0		3	Sandy Top Soil	
	3		45	Brown Clay	
	45		60	Sand fine to med. coarse	
	60		124	Sand, fine to med. coarse small to large gravel, uses water	
				(Rough from 75 - 100')	
	124		133	Brown clay, few rock ledges	
	133		198	Sand fine to med. coarse, small to med. gravel, few large gravel, very few clay stks. Uses water.	
	198		212	Brown & gray clay, gray sand stks.	
	212		274	Blue clay	
50	274	14	288	Sand, fine to med. coarse, small gravel few clay stks.	
70	288	7	295	Sand, fine to med. coarse, small to large gravel	
60	295	33	328	Sand, fine to med. coarse, small to med. gravel, Few small clay stks, cemented in places.	
55	328	9	339	Sand, fine to med. coarse, small gravel, cemented in places, clay stks.	
	339		364	Brown & tan sandy clay	
35	364	4	368	Limerock, fine sand & sandy clay	
	368		392	Brown clay	
30	392	18	410	Brown sandy clay, limerock ledges & fine sand	
	410		436	Brown clay, sticky	
40	436	9	445	Sand, fine to med. coarse, few brown rock clay & stks.	
20	445	2	447	Soapstone & sandstone	
20	447	3	450	Red & Yellow sandstone & soapstone	
	450		460	Soapstone & limestone	
				6" Plastic	TOTAL DEPTH 348'
					Perf. Plain
				348 - 288'	60'
				288 - 0	288'
				300 lbs. Revert	

**GARDEN CITY, KS**      **HENKLE DRILLING & SUPPLY CO., INC.**      **SUBLETTE, KS**  
**Phone 276-3278**      **IRRIGATION HEADQUARTERS**      **Phone 675-4311**  
**TEST HOLES \* \* \* \* \* IRRIGATION & INDUSTRIAL WELLS \* \* \* \* STOCK WELLS**